



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
St Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

August 2, 2021

EMILY B GIBBS
12351 RAVINE CIR N
STILLWATER MN 55082-9214

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1372 PACIFIC ST
Ref. # 122250

Dear Property Representative:

Your building was inspected on August 2, 2021, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on August 25, 2021 at 1:00.P.M. or the property vacated ON AUGUST 31, 2021.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. NEC 110.26 - Provide and maintain a minimum of 36 inches clearance in front of all electrical panels.-
2. r 404.54 - RETAINING WALL S -Retaining walls that are not laterally supported at the top and that retain in excess of 24 inches of unbalanced fill shall be designed to ensure stability against overturning ,sliding , excessive foundation pressure and water uplift.-
3. MMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work SHALL require a permit(s). Call DSI at (651) 266-8989.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector

Ref. # 122250