



August 19, 2022

Cbw Properties Llc
2950 Highland Rd
Mound MN 55364-9464

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1118 MARGARET ST
Ref. # 113150

Dear Property Representative:

Your building was inspected on August 19, 2022, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on September 19, 2022 at 12Noon or the property vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

DEFICIENCY LIST

1. All bedrooms - MSFC 1030.1 - Provide and maintain an approved escape window from each sleeping room or area, or discontinue use of area as a sleeping room. This work may require permit(s). Call DSI at (651) 266-8989.-In every room used for sleeping purposes one window is required of emergency escape and rescue without any obstructions remove all window air conditions.
2. FENCE - SPLC 34.08 (5), 34.32 (3) - All accessory structures including, but not limited to, detached garages, sheds and fences shall be maintained structurally sound and in good repair. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-
3. Garage - SPLC 34.08 (5), 34.32 (3) - All accessory structures including, but not limited to, detached garages, sheds and fences shall be maintained structurally sound and in good repair. Provide and maintain exterior unprotected surfaces painted or protected from the elements.-

4. Kitchen - MSFC 604.4 - Discontinue use of all multi-plug adapters.-
5. Rear deck - SPLC 34.09 (3), 34.33(2) - Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. Every outside stair, porch and deck shall be constructed safely and shall be capable of supporting imposed loads as determined in the building code and shall be kept in a professional state of maintenance and repair with proper anchorage. This work may require a permit(s). Call DSI at (651) 266-8989.-
6. SPLC 39.02(c) - Complete and sign the smoke alarm affidavit and return it to this office.
7. MSFC 307.4 - All fires on the ground must be a minimum of 25 feet from structures or contained in a grill or outdoor fireplace. Wind speeds must be under 10 mph, constantly attended, a means of extinguishment must be provided. Only natural firewood can be burned (no construction materials| brush or waste materials), and fire shall be extinguished if the smoke is deemed a nuisance. A citation will be issued for non-compliance.-
8. SPLC 34.09 (4), 34.33 (3) -All screens shall be maintained in a professional state of maintenance and repair.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector

Ref. # 113150