



Start December 2, 2021 12:14:31 PM
Finish December 2, 2021 12:20:16 PM
Number of Intervals/Interval 5.76/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator

Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.6 volts
Unit Calibration March 18, 2021 by Instantel
Event File Name UM10092_20211202121431.IDFH
USB Sensor Support Disabled





Notes UM10092 MacDonald Montessori School

Location Winslow Apartments
Client
Company
General Notes

Post Event Notes No text to be displayed.

Geophone		Tran	Vert	Long
Peak Particle Velocity	0.1009 in/s	0.1375 in/s	0.1195 in/s	
Zero Crossing Frequency	4.5 Hz	3.9 Hz	2.2 Hz	
Date	Dec 2, 2021	Dec 2, 2021	Dec 2, 2021	
Time	12:20:16 PM	12:20:16 PM	12:20:16 PM	
Sensor Check	Passed	Passed	Passed	Passed
Frequency	7.3 Hz	7.3 Hz	7.1 Hz	7.1 Hz
Overswing Ratio	3.8	4.1	4.5	

Peak Vector Sum 0.1726 in/s at December 2, 2021 12:20:31 PM





Start
 Finish
 Number of Intervals/Interval
 Sample Rate
 Setup File Name
 Operator

December 3, 2021 07:56:30 AM
 December 3, 2021 06:59:59 PM
 663.48/60 sec
 1024 sps
 UM10092.mmb
 Operator

Serial Number
 Model Number
 Battery Level
 Unit Calibration
 Event File Name
 USB Sensor Support

UM10092
 Micromate ISEE 10.90
 3.5 volts
 March 18, 2021 by Instantel
 UM10092_20211203075630.IDFH
 Disabled

Notes
 Location
 Client
 Company

UM10092 MacDonald Montessori School

Winslow Apartments


Post Event Notes No text to be displayed.

Geophone
 Peak Particle Velocity
 Zero Crossing Frequency
 Date
 Time
 Sensor Check
 Frequency
 Overswing Ratio

Tran	Vert	Long
0.0326 in/s 7.5 Hz Dec 3, 2021 07:57:30 AM Passed 7.1 Hz 3.9	0.1455 in/s 7.9 Hz Dec 3, 2021 07:57:30 AM Passed 7.3 Hz 4.1	0.0801 in/s 4.5 Hz Dec 3, 2021 07:57:30 AM Passed 7.1 Hz 4.6

Peak Vector Sum

0.1677 in/s at December 3, 2021 07:57:30 AM





Start December 4, 2021 07:00:08 AM
Finish December 4, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator

Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.8 volts
Unit Calibration March 18, 2021 by Instantel
Event File Name UM10092_20211204070008.IDFH
USB Sensor Support Disabled





Notes
 Location UM10092 MacDonald Montessori School
 Client Winslow Apartments
 Company
 General Notes

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity <0.005 in/s
Zero Crossing Frequency 28.4 Hz
Date Dec 4, 2021
Time 12:15:08 PM
Sensor Check ✔ Passed
Frequency 7.3 Hz
Overswing Ratio 3.9

Long
Peak Particle Velocity <0.005 in/s
Zero Crossing Frequency 28.4 Hz
Date Dec 4, 2021
Time 12:15:08 PM
Sensor Check ✔ Passed
Frequency 7.1 Hz
Overswing Ratio 4.6

Peak Vector Sum 0.0053 in/s at December 4, 2021 12:15:08 PM





Start December 5, 2021 07:00:08 AM
Finish December 5, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator

Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.8 volts
Unit Calibration March 18, 2021 by Instantel
Event File Name UM10092_20211205070008.IDFH
USB Sensor Support Disabled

Notes
Location UM10092 MacDonald Montessori School
Client
Company
General Notes Winslow Apartments





Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity <0.005 in/s
Zero Crossing Frequency 73.1 Hz
Date Dec 5, 2021
Time 05:11:08 PM
Sensor Check **Passed**
Frequency 7.3 Hz
Overswing Ratio 3.9

Tran <0.005 in/s
Vert <0.005 in/s
Long <0.005 in/s
73.1 Hz
Dec 5, 2021
07:13:08 AM
Passed
7.3 Hz
4.1

73.1 Hz
Dec 5, 2021
12:15:08 PM
Passed
7.1 Hz
4.6

Peak Vector Sum 0.0044 in/s at December 5, 2021 12:38:08 PM





Start December 6, 2021 07:00:08 AM
Finish December 6, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator

Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.8 volts
Unit Calibration March 18, 2021 by Instantel
Event File Name UM10092_20211206070008.IDFH
USB Sensor Support Disabled

Notes UM10092 MacDonald Montessori School

Location Winslow Apartments

Client





Company

General Notes

Post Event Notes No text to be displayed.

Geophone	Tran	Vert	Long
Peak Particle Velocity	<0.005 in/s	<0.005 in/s	<0.005 in/s
Zero Crossing Frequency	85.3 Hz	>100 Hz	64.0 Hz
Date	Dec 6, 2021	Dec 6, 2021	Dec 6, 2021
Time	12:18:08 PM	10:35:08 AM	07:48:08 AM
Sensor Check	Passed	Passed	Passed
Frequency	7.3 Hz	7.3 Hz	7.1 Hz
Overswing Ratio	3.9	4.1	4.5

Peak Vector Sum 0.0047 in/s at December 6, 2021 10:35:08 AM





Start December 7, 2021 07:00:08 AM
Finish December 7, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator





Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.8 volts
Unit Calibration March 18, 2021 by Instantel
Event File Name UM10092_20211207070008.IDFH
USB Sensor Support Disabled

Notes
 Location **UM10092 MacDonald Montessori School**
 Client
 Company
 General Notes Winslow Apartments

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity **Tran** **Vert** **Long**
Zero Crossing Frequency <0.005 in/s 0.0053 in/s <0.005 in/s
Date 73.1 Hz 17.1 Hz 51.2 Hz
Time Dec 7, 2021 Dec 7, 2021 Dec 7, 2021
Sensor Check 06:28:08 PM 07:44:08 AM 07:26:08 AM
Frequency **Passed** **Passed** **Passed**
Overswing Ratio 7.3 Hz 7.3 Hz 7.1 Hz
 3.9 4.0 4.5

Peak Vector Sum 0.0053 in/s at December 7, 2021 07:44:08 AM





Start December 8, 2021 07:00:08 AM
Finish December 8, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM10092
 Micromate ISEE 10.90
 3.8 volts
 March '18, 2021 by Instantel
 UM10092_20211208070008.IDFH
 Disabled


Notes
Location UM10092 MacDonald Montessori School
Client
Company
General Notes Winslow Apartments

Post Event Notes No text to be displayed.




Geophone
Peak Particle Velocity
Zero Crossing Frequency
Date
Time
Sensor Check
Frequency
Overswing Ratio

Tran	<0.005 in/s	Vert	<0.005 in/s	Long	<0.005 in/s
>100 Hz	19.7 Hz	>100 Hz	19.7 Hz	>100 Hz	>100 Hz
Dec 8, 2021	Dec 8, 2021	Dec 8, 2021	Dec 8, 2021	Dec 8, 2021	Dec 8, 2021
08:15:08 AM	03:13:08 PM	07:02:08 AM	07:02:08 AM	07:02:08 AM	07:02:08 AM
Passed	Passed	Passed	Passed	Passed	Passed
7.3 Hz	7.3 Hz	7.1 Hz	7.1 Hz	7.1 Hz	7.1 Hz
3.9	4.0	4.5	4.5	4.5	4.5

Peak Vector Sum 0.0045 in/s at December 8, 2021 10:03:08 AM



Sensor CI





Start December 9, 2021 07:00:08 AM
Finish December 9, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator

Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.8 volts
Unit Calibration March 18, 2021 by InstanTel
Event File Name UM10092_20211209070008.IDFH
USB Sensor Support Disabled

Notes
 Location **UM10092 MacDonald Montessori School**
 Client
 Company
General Notes Winslow Apartments





Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity <0.005 in/s
Zero Crossing Frequency 85.3 Hz
Date Dec 9, 2021
Time 09:27:08 AM
Sensor Check ✔ Passed
Frequency 7.1 Hz
Overswing Ratio 4.5

Tran
>100 Hz <0.005 in/s
 Dec 9, 2021 24.4 Hz
07:45:08 AM Dec 9, 2021
✔ Passed 08:17:08 AM
7.3 Hz 7.3 Hz
3.9 4.0

Long
<0.005 in/s <0.005 in/s
 85.3 Hz
 Dec 9, 2021
09:27:08 AM Dec 9, 2021
✔ Passed 09:27:08 AM
7.1 Hz 7.1 Hz
4.5 4.5

Peak Vector Sum 0.0051 in/s at December 9, 2021 08:17:08 AM





Start December 10, 2021 07:00:08 AM
Finish December 10, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator

Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.8 volts
Unit Calibration March 18, 2021 by InstanTel
Event File Name UM10092_20211210070008.IDFH
USB Sensor Support Disabled

Notes
Location MacDonalld Montessori School
Client
Company Winslow Apartments
General Notes


Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity <0.005 in/s
Zero Crossing Frequency >100 Hz
Date Dec 10, 2021
Time 08:08:08 AM
Sensor Check ✔ Passed
Frequency 7.3 Hz
Overswing Ratio 3.9




Tran <0.005 in/s
 73.1 Hz
 Dec 10, 2021
 12:06:08 PM
✔ Passed
 7.3 Hz
 3.9

Long <0.005 in/s
 >100 Hz
 Dec 10, 2021
 03:37:08 PM
✔ Passed
 7.1 Hz
 4.5

Peak Vector Sum 0.0055 in/s at December 10, 2021 08:08:08 AM



Sensor CI
+ Tran x Vert ø Long





Start December 11, 2021 07:00:08 AM
Finish December 11, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator

Serial Number
Model Number
Battery Level
Unit Calibration
Event File Name
USB Sensor Support

UM10092
 Micromate ISEE 10.90
 3.8 volts
 March 18, 2021 by Instantel
 UM10092_20211211070008.IDFH
 Disabled

Notes
Location UM10092 MacDonald Montessori School
Client
Company
General Notes Winslow Apartments

Post Event Notes No text to be displayed.





Geophone
Peak Particle Velocity <0.005 in/s
Zero Crossing Frequency 85.3 Hz
Date Dec 11, 2021
Time Dec 11, 2021 08:56:08 AM
Sensor Check ✔ Passed
Frequency 7.3 Hz
Overswing Ratio 3.9

Tran <0.005 in/s
 >100 Hz
 Dec 11, 2021 12:19:08 PM
✔ Passed
 7.3 Hz
 3.9

Vert 0.0056 in/s
 >100 Hz
 Dec 11, 2021 10:08:08 AM
✔ Passed
 7.3 Hz
 4.0

Long <0.005 in/s
 85.3 Hz
 Dec 11, 2021 08:56:08 AM
✔ Passed
 7.1 Hz
 4.5

Peak Vector Sum 0.0059 in/s at December 11, 2021 12:08:08 PM





Start December 12, 2021 07:00:08 AM
Finish December 12, 2021 06:59:59 PM
Number of Intervals/Interval 719.85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator





Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.8 volts
Unit Calibration March 18, 2021 by Instantel
Event File Name UM10092_20211212070008.IDFH
USB Sensor Support Disabled

Notes
Location UM10092 MacDonald Montessori School
Client
Company Winslow Apartments
General Notes

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity **Tran** **Vert** **Long**
Zero Crossing Frequency <0.005 in/s <0.005 in/s <0.005 in/s
Date >100 Hz >100 Hz >100 Hz
Time Dec 12, 2021 Dec 12, 2021 Dec 12, 2021
Sensor Check 09:58:08 AM 08:12:08 AM 07:10:08 AM
Frequency **Passed** **Passed** **Passed**
Overswing Ratio 7.3 Hz 7.3 Hz 7.1 Hz
 3.9 4.0 4.5

Peak Vector Sum 0.0045 in/s at December 12, 2021 11:06:08 AM





Start December 13, 2021 07:00:08 AM
Finish December 13, 2021 06:59:59 PM
Number of Intervals/Interval 7:19:85/60 sec
Sample Rate 1024 sps
Setup File Name UM10092.mmb
Operator Operator

Serial Number UM10092
Model Number Micromate ISEE 10.90
Battery Level 3.8 volts
Unit Calibration March 18, 2021 by InstanTel
Event File Name UM10092_20211213070008.IDFH
USB Sensor Support Disabled

Notes
Location MacDonalD Montessori School
Client
Company
General Notes Winslow Apartments

Post Event Notes No text to be displayed.

Geophone
Peak Particle Velocity <0.005 in/s
Zero Crossing Frequency >100 Hz
Date Dec 13, 2021
Time 07:47:08 AM
Sensor Check ✔ Passed
Frequency 7.3 Hz
Overswing Ratio 3.9

Long
Peak Particle Velocity <0.005 in/s
Zero Crossing Frequency >100 Hz
Date Dec 13, 2021
Time 11:35:08 AM
Sensor Check ✔ Passed
Frequency 7.1 Hz
Overswing Ratio 4.5

Peak Vector Sum 0.0078 in/s at December 13, 2021 11:35:08 AM

