



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

November 3, 2022

BOYEYEH HOLDINGS LLC
3853 CENTRAL AVENUE NE
MINNEAPOLIS MN 55421-3930

**NOTICE OF CONDEMNATION BECAUSE OF BASIC
FACILITIES
UNFIT FOR HUMAN HABITATION
ORDER TO VACATE**

RE: 1093 EUCLID ST
Ref. # 108655

Dear Property Representative:

Your building was inspected on November 3, 2022.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

1. SPLC 34.14 (2)(A), 34.34 (5)(A) - Provide an approved electrical service adequate to meet the building's needs. Contact Xcel and have your service restored by close of business November 3, 2022-
2. SPLC 39.02(c) - Complete and sign the smoke alarm affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector
Ref. # 108655