



Fire Inspection Report

City of Saint Paul

Department of Safety and Inspections
375 Jackson Street – Suite 220
Saint Paul MN 55101-1806

Owner Name ATNAFU YESHIDAGAE
Owner Address ATNAFU2001@gmail.com
City State Zip _____
Owner Phone 612-408-4096

License CONTRACTOR DJ
Complaint 612-790-2941
C of O _____
Date 3/9/2023

Building Address: 510 SNELLING AVE NORTH

You are hereby notified to remedy the conditions stated below immediately. A reinspection will be made after the reinspection date stated below. If you consider any of these code requirements to be unreasonable, you may appeal to the Legislative Hearing Officer. Applications for appeals may be obtained at the City Clerks Office, 310 City Hall 651-266-8585 within 10 days of the date of the original orders.

Code	Conditions to be Corrected
MSBC	OBTAIN INSPECTIONS FOR CONSTRUCTION IN 506 SNELLING AVE - MAY NEED TO OPEN WALLS AND CEILING (ADD BOLLARDS; AC PAD)
MMC	OBTAIN INVOICE AND PROTECT PROPOSAL FOR VENTILATION CORRECTIONS AN EXHAUST DUCT WORK AND FAN ASSEMBLY, CONTRACTOR TO SUBMIT PLANS TO WARM-AIR INSPECTIONS FOR REVIEW AND PERMIT ISSUING, PROVIDE COPY OF PROPOSAL TO LHO.
MSPC	GAS PLUMBING INSPECTION REQUIRED FOR INSTALLATION OF GAS RANGE.
MSPC	ANNUAL SYSTEM IS OVERDUE, CONTACT CONTRACTOR AND HAVE THIS SERVICED - IMMEDIATELY.

Owner or Representative Signature _____

Occupancy Type BUSINESS

Inspector Signature Jaura Huseby

CFO Key _____

Reinspection Date TBD

* * For further information on this report, contact the Fire Inspection Division at 651-266-8989 * *