



APPLICATION FOR APPEAL

RECEIVED

APR 02 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, April 10, 2012

Time 1:30 p.m.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 793 Iglehart Ave City: St. Paul State: MN Zip: 55104

Appellant/Applicant: Tony Swanson Email anthony.swanson@stpha.org

Phone Numbers: Business 651-298-4907 Residence _____ Cell _____

Signature: [Signature] Date: 4-2-12

Name of Owner (if other than Appellant): Public Housing Agency of St. Paul

Address (if not Appellant's): 555 N. Wabasha Suite # 400 St. Paul, MN 55102

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

#2 Double hung Windows - MSFC 1026.1
Request variance on operable height.

C: B. YANG
P. CLARKIN
T. SWANSON

DEPARTMENT OF SAFETY AND INSPECTIONS
Fire Inspection Division
Ricardo A. Cervantes, Director



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

March 14, 2012

PUBLIC HOUSING AGENCY
555 WABASHA ST N STE 400
ST PAUL MN 55102

FIRE INSPECTION CORRECTION NOTICE

RE: 793 IGLEHART AVE
Residential Class: C

Dear Property Representative:

Your building was inspected on March 14, 2012 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date. A re-inspection will be made on April 11, 2012 at 1:30 PM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

- B. YANG - WDH# 1127856**
1. Basement steps - MSFC 104.9, 1005.3.2.2 - Remove the storage under the stairs or provide and maintain 1 hour fire resistive construction on the storage side of the stairs.
 2. Double hung windows - MSFC 1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information. - **P. CLARKIN / T. SWANSON - WDH# 1127857**
Northeast
22.5 h x 41 w Glazed 12.0 sq ft
Northwest

An Equal Opportunity Employer

- 22.5 h x 41 w Glazed 12.0 sq ft
South
22.5 h x 41 w Glazed 12.0 sq ft
B. VANG - WO# 1127858
3. East entry door - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.-Discontinue storage of shoes on the ground in exitway.
B. VANG - WO# 1127859
4. Northeast bedroom - Window - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.
B. VANG - WO# 1127860
5. Northeast bedroom - MSFC 1011.2 - Remove the materials that cause an exit obstruction. Maintain a clear and unobstructed exitway.-immediately move bed that prevents door from fully opening.
B. VANG - WO# 1127861
6. Sleeping rooms - SPLC 34.13 (3), SPLC 34.17 (2) - Reduce and maintain the number of occupants in the sleeping rooms to:-One person in the south bedroom (85 square feet). One person in the northeast bedroom (85 square feet). Two people in the northwest bedroom (118 square feet).
P. CLARK, JR - PROVIDE DOCUMENTATION TO NANCY
7. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
N. Schmiot
8. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector