

Scanned



APPLICATION FOR APPEAL

RECEIVED
JAN 17 2012
CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, JANUARY 24
2012

Time 1:30 pm

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 998 Randolph Ave City: St. Paul State: MN Zip: 55102

Appellant/Applicant: Ronald Drexel Email _____

Phone Numbers: Business _____ Residence 715-381-6768 Cell 651-402-0411

Signature: Ronald Drexel Date: 1/17/12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

See attached form / Need to get variance



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 1/12/12

APPEAL PROPERTY ADDRESS: 998 Randolph Ave.

APPLICANT NAME: _____ PHONE NUMBER: _____

PERMIT NUMBER: _____

TYPE OF WINDOW: Slider

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: 105 sq ft

DIFFERENCE FROM REQUIRED AREA: OK

WIDTH OF OPENING: 17.5"

DIFFERENCE FROM REQUIRED OPENING: -2.5"

HEIGHT OF OPENING: 42"

DIFFERENCE FROM REQUIRED OPENING: +18" OK

HEIGHT OF OPENING
TO FINISHED FLOOR: 21"

DIFFERENCE FROM MAXIMUM HEIGHT: OK

COMMENTS: Window installed

FROM: David Tank
651-266-9020