



APPLICATION FOR APPEAL

RECEIVED

MAR 30 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number 905321)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☐ This appeal form completed
- ☒ Walk-In OR ☐ Mail-In

YOUR HEARING Date and Time:

Tuesday, 4-10-12

Time 1:30 P.M.

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 1717 Burns Ave City: ST. Paul State: MN Zip: 55106

Appellant/Applicant: Jeffrey P. Weinzeil Email Jeff.Weinzeil@CHSINC.COM

Phone Numbers: Business 651-355-4568 Residence 651-772-2037 Cell 651-285-2567

Signature: [Signature] Date: 3/28/12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- ☐ Vacate Order/Condemnation/
Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

See attachment.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: 3/29/12

APPEAL PROPERTY ADDRESS: 1717 Burns Ave ST. Paul, MN 55106

APPLICANT NAME: Jeff Weinzel PHONE NUMBER: 651-772-2037

PERMIT NUMBER: 2012 00 2521

TYPE OF WINDOW: Casement

NUMBER OF WINDOWS: 1

TOTAL GLAZED AREA: ~~624~~ " 576

DIFFERENCE FROM REQUIRED AREA: ~~-197~~ " -245"

WIDTH OF OPENING: ~~30~~ " 24

DIFFERENCE FROM REQUIRED OPENING: -4"

HEIGHT OF OPENING: ~~30~~ " 24

DIFFERENCE FROM REQUIRED OPENING: 0

HEIGHT OF OPENING
TO FINISHED FLOOR: 44"


DIFFERENCE FROM MAXIMUM HEIGHT: +4

RECOMMENDATION (IF APPLICABLE): _____

FROM: _____

Attachment 1:

- 1) Owner occupied portion of housing
- 2) Creating large open will weaken Stucco integrity. (outside)
- 3) Existing electrical wiring under window opening may need to be moved.
- 4) Requesting exception based on policy when remodeling and wanting to replace previously installed window with same size + type of window (casement). Dimensions supplied on enclosed application.



CITY OF SAINT PAUL BUILDING

PERMIT # : 20 12 002521

CONTRACTOR:

Jeffrey P Weinzetl

ISSUED DATE: 01/09/2012

TYPE OF WORK:

Residential (Multi-Fam) - Remodel

JOB SITE ADDRESS:

1717 BURNS AVE

BUILDING INSPECTOR: Nelson, Dave P.

PHONE: 651-266-9027

MINIMUM INSPECTIONS REQUIRED

1. Soil, foundation, footings, reinforcement and erosion control as specified.
2. Rough-in for all trades prior to framing inspection.
3. Framing - prior to covering structural members.
4. Insulation and vapor retarder prior to covering.
5. Sheetrock that is part of a fire-resistive or shear assembly.
6. Final - prior to occupancy.

INSPECTION APPROVALS

Call between 7:30 - 9:00 am to arrange for inspection.
Post this inspection record at the job site until final approval.
No building shall be occupied without inspector approval.
Work shall not proceed without inspector approval.
Approved plans must be retained on the job site.

SEPARATE PERMIT REQUIRED FOR WORK OF EACH TRADE.

Building Inspection: 651-266-9002

An erosion control inspection is required for land disturbances greater than 50 cu. yds.
Controls must be installed, inspected and approved prior to beginning excavation.

Soil Erosion Control:	Insulation:
Footings:	Sheetrock:
Framing:	Final:
Electrical Inspection: 651-266-9003	
Rough-in:	Final:
Mechanical Inspection: 651-266-9004	
Rough-in:	Final:
Plumbing Inspection: 651-266-9005	
Rough-in:	Final:
Warm Air/Ventilation Inspection: 651-266-9006	
Rough-in:	Final:
Elevator Inspection: 651-266-9010	
Rough-in:	Final:
Fire Inspection: 651-266-9090	
Rough-in:	Final: