



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED
JAN 17 2012
CITY CLERK

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed
- ☐ Walk-In OR ☒ Mail-In

YOUR HEARING Date and Time:

Tuesday, 1-24-12

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

*emailed notice 1/17/12
jane*

Address Being Appealed:

Number & Street: 1810 Marshall Ave City: St. Paul State: MN Zip: 55104

Appellant/Applicant: Judd Andrews Email: jandrewse@fireproz.com

Phone Numbers: Business 651-430-0099 Residence N/A Cell 651-245-3388

Signature: [Signature] Date: 1/10/12

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): 1900 Henlock Pl, Hudson, WI 54016

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other

Grandfathered in



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

December 5, 2011

Judd D Andrews
1900 Hemlock Place
Hudson WI 54016-7275

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
1810 MARSHALL AVE

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on December 5, 2011. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately.

A reinspection will be made on December 27, 2011 at 1:30 pm.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. Basement - Behind refrigerator - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.
2. Basement - Behind refrigerator - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090.
3. Basement - Behind refrigerator - MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-
South double hung
12.25 h x 32 w glazed 8.7 sq ft
West double hung
20 h x 39 w Glazed 11.4 sq ft

East double hung
20 h x 39 w Glazed 11.4 sq ft

Basement
Glass block window

4. Basement - Behind refrigerator - SPLC 34.23, MSFC 110.1 - This basement is condemned as unsafe or dangerous as a sleeping area. This basement must not be used as a sleeping area until re-inspected and approved by this office.
5. Basement - light - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090.
6. Basement - NEC 110-26 - Provide and maintain a minimum of 36 inches clearance in front of all electrical panels.
7. Basement - MSFC 315.2.5 - Fueled equipment, including but not limited to motorcycles, mopeds, lawn-care equipment and portable cooking equipment, shall not be stored, operator or repaired within a building.-Remove and discontinue storage of snow blower from the interior.
8. Basement steps - SPLC 34.10 (3) 34.33(2) - Provide an approved guardrail. Intermediate ballustrade must not be more than 4 inches apart. Intermediate rails must be provided if the height of the platform is more than 30 inches.
9. Exterior - Front - SPLC 71.01 - The address posted is not visible from street. (HN-1)- Provide address numbers that contrast with the background.
Provide reflective numbers or background or illuminate at night.
10. Exterior - Front - SPLC 34.14 (2) f - Provide and maintain an minimum of 1 foot candle at the grade level of exterior exits and entryways for security. This work may require a permit(s). Call DSI at (651) 266-9090.-New light being installed on front porch under permit, contact electrical inspector for approval when this work is completed.
11. Exterior - Rear - SPLC 71.01 - Provide address numbers on building per attached HN-1 handout.-Provide address numbers visible from the alley side of the building.
12. Exterior - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Repair fire damage to front porch in an approved manner.
Scrape and paint siding and trim throughout the exterior as necessary wherever chipped or peeling.
13. Exterior - SPLC 34.09 (3), 34.32 (3) - Provide or repair and maintain the window screens.

14. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
15. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
16. SPLC 40.04 (5) On or after April 30, 2009, The owner of a building used for residential occupancy who is applying for their FIRST Fire Certificate of Occupancy, must complete the Minnesota Crime Free Multi Housing training program or other landlord training program approved by the Fire Marshal.
The training must have occurred within the last two years and the owner must submit a certificate of attendance or provide verification of enrollment in the next scheduled class to the Fire Inspection Division-DSI.
This requirement shall not apply to an owner who has held a Fire Certificate of Occupancy on another residential property in Saint Paul prior to April 30, 2009.
17. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector