

RLH VO 23-11



APPLICATION FOR APPEAL

Saint Paul City Council – Legislative Hearings

RECEIVED

MAR 06 2023

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8585

We need the following to process your appeal:

CITY CLERK

- ☒ \$25 filing fee (non-refundable) (payable to the City of Saint Paul)(if cash: receipt number _____)
 - ☒ Copy of the City-issued orders/letter being appealed
 - ☒ Attachments you may wish to include
 - ☒ This appeal form completed
 - ☒ Walk-In OR ☐ Mail-In
- for abatement orders only: ☐ Email OR ☐ Fax

HEARING DATE & TIME

(provided by Legislative Hearing Office)

Tuesday, March 14, 2023

Location of Hearing:

☐ Telephone: you will be called between _____ & _____

☒ In person (Room 330 City Hall) at: 1:30pm.
(required for all Fire C of O revocation & vacate; Condemnation orders)

Address Being Appealed:

Number & Street: 1355 EUSTIS ST. #2 City: ST. PAUL State: MIN Zip: 55108

Appellant/Applicant: WARREN ENRIGHT Email _____

Phone Numbers: Business _____ Residence 651-917-8292 Cell 651-338-5569

Signature: Warren J. Enright Date: March 6, 2023

Name of Owner (if other than Appellant): EQUIMAX Real Estate

Mailing Address if Not Appellant's: Mendelsohn Ave No. - Golden Valley

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why?

Attachments Are Acceptable

- ☒ Vacate Order/Condemnation/Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List/Correction
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other (Fence Variance, Code Compliance, etc.)

Too much material in unit



March 3, 2023

Equimax Real Estate
1200 MENDELSSOHN AVE N SUITE 210
GOLDEN VALLEY MN 55427USA

**NOTICE OF CONDEMNATION
UNFIT FOR HUMAN HABITATION
ORDER TO VACATE**

RE: 1355 EUSTIS ST
Ref. # 14177

Dear Property Representative:

Your building was inspected on March 3, 2023.

The unit was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed, or the unit vacated by the re-inspection date.

A reinspection will be made on March 31, 2023, at 1:30 pm.

CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

DEFICIENCY LIST

1. Interior - Unit 2 - MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials. -Reduce content by 50%.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: Jack.Toeller@ci.stpaul.mn.us or call me at 651-266-8950 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

Jack Toeller
Fire Inspector
Ref. # 14177

cc: Housing Resource Center
Force Unit



CITY OF SAINT PAUL

375 Jackson Street, Suite 220
St Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-9124
Web: www.stpaul.gov/dsi

February 10, 2023

St Anthony Park Apts Llc
1161 Wayzata Blvd Ste 312
Wayzata MN 55391-1935

RE: RE-INSPECTION FIRE CERTIFICATE OF OCCUPANCY WITH DEFICIENCIES
1355 EUSTIS ST

Ref. # 14177

Dear Property Representative:

Your building was re-inspected for the Fire Certificate of Occupancy on February 10, 2023. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected immediately. **A reinspection will be made on March 2, 2023, at 9:30 am.**

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. Interior - Unit 2 - MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials. -Reduce content by 50%.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at Jack.Toeller@ci.stpaul.mn.us or call me at 651-266-8950 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Jack Toeller
Fire Inspector
Ref. # 14177