



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220 Telephone: 651-266-8989
Saint Paul, MN 55101-1806 Fax: 651-266-8951

January 12, 2012

BROTHERS FIRE PROTECTION CO
9950 HIGHWAY 10 E
ELK RIVER MN 55330

Re: Sprinkler / Standpipe Permit Inspection
408 ST PETER ST
Permit # 2011-287757 SSP
PROVIDE ADDITION AREA OF COVERAGE TO BASEMENT AS PART OF WORK TO FUTURE
PERMIT 11-271295. ADD THIS TO SUBMITTAL

Dear Contractor:

An inspection was done at the above mentioned premise on January 12, 2012.

The following deficiencies were noted during the inspection and must be corrected to attain final approval:

1. NFPA 13 (2002) 8.6.6.1 - Maintain a distance of at least 18 inches between the top of storage and the sprinkler deflector. Costume storage area.
2. Rehearsal hall is not installed according to the submitted plan - verify the locations of the sprinklers in this room. See NFPA 13 2002 ed. sec 8.6.4.1 and 8.6.5.

When these deficiencies are corrected, please call me at 651-266-8954 for a re-inspection.

Sincerely,

Katie LeTourneau-Bjorge
Fire Inspector
Email: katie.letourneau-bjorge@ci.stpaul.mn.us