



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 7-12-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 789 Nevada Ave E City: St. Paul State: MN Zip: 55106

Appellant/Applicant: Renewal by Andersen Email bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Craig & Connie Hecht

Address (if not Appellant's): 789 Nevada Ave E

Phone Numbers: Business _____ Residence 651-716-7051 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other
- Other
- Other

We are appealing 5 replacement window that will not comply w/ Egress requirements. Windows will have opening height will be short by 1" & 5" but operable width will be exceeded by 4" & 8" respectively. Please Approve. Homeowners would like to keep style consistent



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 22, 2011

APPEAL PROPERTY ADDRESS: 789 NEVADA AVE E

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 11 242508

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	10.5	Difference from Required Area	+5.5
Width of Opening Minimum 20 Inches	24	Difference from Required Opening	+4
Height of Opening Minimum 24 Inches	23	Difference from Required Opening	-1
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. 6-22-11 rr

Reviewed by: Rehn



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 22, 2011

APPEAL PROPERTY ADDRESS: 789 NEVADA AVE E
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 242508
TYPE OF WINDOW: Double hung
NUMBER OF WINDOWS: 2

Total Glazed Area Minimum 5 Square Feet	12	Difference from Required Area	+7
Width of Opening Minimum 20 Inches	28	Difference from Required Opening	+8
Height of Opening Minimum 24 Inches	23	Difference from Required Opening	-1
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. 6-22-11

Reviewed by: Rehn



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: June 22, 2011

APPEAL PROPERTY ADDRESS: 789 NEVADA AVE E
APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION
PHONE NUMBER: 651-264-4914
PERMIT NUMBER: 11 242508
TYPE OF WINDOW Double hung
NUMBER OF WINDOWS 1

Total Glazed Area Minimum 5 Square Feet	10.2	Difference from Required Area	+5.2
Width of Opening Minimum 20 Inches	28	Difference from Required Opening	+8
Height of Opening Minimum 24 Inches	19	Difference from Required Opening	-5
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	36	Difference from Maximum Height	ok

COMMENTS: With the information provided above, approval is recommended. ^{5-22-11 rr}
_{6-22-11 RR}

Reviewed by: Rehn