



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8560 FAX: (651) 266-8574

March 11, 2011

Window Concepts of Minnesota Inc
990 Lone Oak Road Ste 114
Eagan MN 55121-0000
952-883-0476

jseib@windowconceptsmin.com

Re: Appeal for property at 675 Arlington Avenue East
File ID: ALH 11-338

Dear Joanne:

This is to confirm that the Legislative Hearing Officer reviewed the above-referenced appeal and recommended granting a 4.25-inch variance on the openable height of one double hung replacement egress bedroom window which measured at 19.75 inches high by 28.75 inches wide.

If you have further questions, please contact me at 651-266-8563.

Sincerely,

/s/

Mai Vang
Legislative Hearing Coordinator

c: Fire Supervisors (email)
Jim Bloom (email)
Stephen Ubl (email)
File

