



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street., Suite 220
Saint Paul, MN 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-1919
Web: www.stpaul.gov/dsi

362

March 27, 2012

11-239288

Arthur Rinehart
2183 Barclay St
Maplewood MN 55109-3501

Order to Abate Nuisance Building(s)

Dear Sir or Madam:

The Vacant/Nuisance Buildings Unit, Department of the Department of Safety and Inspections, Division of Code Enforcement, hereby declares the premises located at:

779 CENTRAL AVE W

With the following Historic Preservation information: NONE

and legally described as follows, to wit:

Butterfield Syndicateadd No 1 Lot 12 Blk 8

to comprise a nuisance condition in violation of the Saint Paul Legislative Code, Chapter 45.02, and subject to demolition under authority of Chapter 45.11.

On March 21, 2012 a Building Deficiency Inspection Report was compiled and the following conditions were observed.

This list of deficiencies is not necessarily all the deficiencies present at this time. This building(s) is subject to the restrictions of Saint Paul Ordinance Chapter 33.03 and shall not again be used for occupancy until such time as a Certificate of Compliance or a Certificate of Occupancy has been issued. All repairs must be in accordance with appropriate codes. Changes or additions to the electrical system, mechanical system, or the plumbing system may necessitate updating or upgrading the systems involved.

This is a one-story, wood frame, commercial building with a two-stall, detached wood frame garage.

The following Deficiency List is excerpted from the January 4, 2011 Fire Certificate of Occupancy Deficiency List.

1. BASEMENT - MN Stat 299F.18 - Immediately remove and discontinue excessive accumulation of combustible materials.
2. BASEMENT - MSFC 315.2.3 - Remove combustible storage from the fuel burning equipment rooms.
3. FRONT DOOR - SPLC 34.09 (3), 34.32 (3) - Repair and maintain the door latch.
4. GENERAL - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.
5. GENERAL - MSFC 605.1 - Repair or replace damaged electrical fixtures. This work may require a permit(s). Call DSI at (651) 266-9090.-lights in ceiling must be installed per electrical code, under permit by electrician.
6. GENERAL - MSFC 605.1 - Remove unapproved exposed wiring and install in accordance with the electrical code. This work may require a permit(s). Call DSI at (651) 266-9090.
7. GENERAL - MSFC 605.4 - Discontinue use of all multi-plug adapters.
8. GENERAL - MSFC 605.5 - Discontinue use of extension cords used in lieu of permanent wiring.
9. GENERAL - SPLC 34.10 (4), 34.33 (3) - Provide a bathroom floor impervious to water.
10. GENERAL - MSFC 315.2 - Provide and maintain orderly storage of materials.- Throughout
11. GENERAL - MSFC 315.2.5 - Fueled equipment, including but not limited to motorcycles, mopeds, lawn-care equipment and portable cooking equipment, shall not be stored, operator or repaired within a building.-Lawnmower and snow blower
12. GENERAL - SPLC 33.05 - Post the provided Certificate of Occupancy in an approved location.
13. GENERAL - MSBC 110.1-REVOCATION
14. OUTSIDE - SPLC 34.09 (1) b,c, 34.32 (1) b,c - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.-Repair siding that is missing.

As owner, agent or responsible party, you are hereby notified that if these deficiencies and the resulting nuisance condition is not corrected by **April 27, 2012** the Department of Safety and Inspections, Division of Code Enforcement, will begin a substantial abatement process to demolish and remove the building(s). The costs of this action, including administrative costs and demolition costs will be assessed against the property taxes as a special assessment in accordance with law.

As first remedial action, a Code Compliance Inspection Report must be obtained from the Building Inspection and Design Section, 375 Jackson Street, Suite 220, (651) 266-8989. This inspection will identify specific defects, necessary repairs and legal requirements to correct this nuisance condition. You may also be required to post a five thousand dollar (\$5,000.00) performance bond with the Department of Safety and Inspections before any permits are issued, except for a demolition permit. Call the Department of Safety and Inspections for more information at 651-266-8989.

If this building is located in a historic district or site (noted on page 1, above, just below the property address) then you must contact Heritage Preservation (HPC) staff to discuss your proposal for the repairs required by this order and compliance with preservation guidelines. Copies of the guidelines and design review application and forms are available from the Department of Safety and Inspections web site (see letterhead) and from the HPC staff. No permits will be issued without HPC review and approval. HPC staff also can be reached by calling 651-266-9078.

As an owner or responsible party, you are required by law to provide full and complete disclosure of this "Order to Abate" to all interested parties, all present or subsequent renters and any subsequent owners. The property shall not be sold, transferred or conveyed in any manner until the Nuisance Conditions have been abated and the Certificate of Code Compliance or Certificate of Occupancy has been issued.

The Enforcement Officer is required by law to post a placard on this property which declares it to be a "nuisance condition", subject to demolition and removal by the City. This placard shall not be removed without the written authority of the Department of Safety and Inspections, Division of Code Enforcement. The department is further required to file a copy of this "Order to Abate" with the City Clerk's Office.

If corrective action is not taken within the time specified in this order, the Enforcement Officer will notify the City Council that abatement action is necessary. The City Clerk will then schedule dates for Public Hearings before the City Council at which time testimony will be heard from interested parties. After this hearing the City Council will adopt a resolution stating what action if any, it deems appropriate.

If the resolution calls for abatement action the Council may either order the City to take the abatement action or fix a time within which this nuisance must be abated in accordance with the provisions of Chapter 33 of the Saint Paul Legislative Code and provide that if corrective action is not taken within the specified time, the City shall abate this nuisance. The costs of this action, including administrative costs will be assessed against the property as a special assessment in accordance with law.

March 27, 2012
779 CENTRAL AVE W
page 4

If you have any questions or request additional information please contact **Mike Kalis** between the hours of 8:00 and 9:30 a.m. at **651-266-1929**, or you may leave a voice mail message.

Sincerely,

Mike Kalis
Vacant Buildings Enforcement Inspector

cc: Legistar Approval list and City Council

ota60135 5/11