SPFD Daily Fire Investigation Cases

Case Number	Case Name	Location Street Number	Incident Disposition	Fire Fire Spread Materials	Investigation Case Background	Investigator	Case Status
Start Date: 06/10/202	21						
SPFD210610023745	N/A	879 Fremont	Accidental	Confined to building of origin	The fire department was called to the report of a fire in a commercial structure. Firefighters arrived and found fire on the North East corner of the structure. Firefighters searched the structure, extinguished the fire and conducted overhaul. Car 9 was called to the scene and completed the investigation with Squad 3. Investigation found the area of origin to be the stud space containing the electrical wiring for both the air conditioning unit and the walk in cooler for the store. The fire extended from the stud space upwards and outwards to the exterior and into the attic space above. Examination of the electrical panel found the breakers for the cooler were tripped most likely due to extended use of the cooler and air conditioning during the extended period of high temperatures. Command was terminated after completion of the investigation and the scene was released.	Roy Mokosso	Open
SPFD210610023805	021- 117- 605	19 Exchange	Incendiary	Confined to object of origin	The fire department was called to the report of a general fire alarm activation. Firefighters arrived and found an activated sprinkler head in the boys bathroom. Firefighters evacuated the structure, placed a sprinkler stop in the sprinkler, and called for an investigator. Command was terminated and the scene was released.	Mark Affolter	Consult
SPFD210610023904	N/A	800 Transfer	Accidental		The fire department was called to the report of a waterflow alarm. Firefighters arrived and found a visual strobe and audible alarm. Firefighters made entry into the building and were met with high heat conditions but no active fire and a sprinkler activation. Further investigation found no signs of fire. Command was terminated and the scene was released.	Mark Affolter	Consult
SPFD210610023926	N/A	584 Magnolia	Undetermined	Confined to floor of origin	The fire department was called to the report of a fire in a large 2 story multi family dwelling. Firefighters arrived and found heavy smoke conditions coming from the roof line soffit area. SQ1 Firefighters made sure the occupants were evacuated from the structure. SQ1 entered the structure from the Alpha side and advanced up the stairs to the second floor where the smoke was coming from. SQ1 forced the door to the apartment and extinguished the fire. The fire was the heaviest in the living room space and extended into the ceiling of the entire second floor and showed heavy charring on the legacy balloon frame construction. The living space where	Thomas Bever	Open

1 of 2 Printed On: 06/11/2021 08:30:29 AM

Case Number	Case Name	Location Street Number	Incident Disposition	Fire Fire Spread Materials	Investigation Case Background	Investigator	Case Status
					the fire began, had a large amount of collectable toys and memorabilia. Firefighters used salvage tarps to cover the occupants personal property. Firefighters also relocated some items packed away in boxes that were on the floor to protect them. After salvage operations and the fire investigation were complete, firefighters conducted overhaul. Command was terminated and the scene was released.		
Count: 4							
Count: 4							

Report Criteria

Start Date: Is Between Yesterday and Today

2 of 2 Printed On: 06/11/2021 08:30:29 AM