



APPLICATION FOR APPEAL

RECEIVED

JAN 12 2012

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- ☒ \$25 filing fee payable to the City of Saint Paul
(if cash: receipt number _____)
- ☒ Copy of the City-issued orders or letter which
are being appealed
- ☐ Attachments you may wish to include
- ☒ This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 1-24-12

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

*emailed hearing to 1-24-12
garnes*

Address Being Appealed:

Number & Street: 1389 Schlettli Street City: St. Paul State: MN Zip: 55117

Appellant/Applicant: Renewal by Andersen Email: bryan.horton@andersencorp.com

Phone Numbers: Business 651-264-4088 Residence _____ Cell _____

Signature: [Signature] Date: _____

Name of Owner (if other than Appellant): Jim Johnson and Crystal Johnson

Address (if not Appellant's): 1389 Schlettli Street

Phone Numbers: Business _____ Residence 651-487-5051 Cell _____

What Is Being appealed and why? Attachments Are Acceptable

- ☐ Vacate Order/Condemnation/
- ☐ Revocation of Fire C of O
- ☐ Summary/Vehicle Abatement
- ☐ Fire C of O Deficiency List
- ☒ Fire C of O: Only Egress Windows
- ☐ Code Enforcement Correction Notice
- ☐ Vacant Building Registration
- ☐ Other
- ☐ Other
- ☐ Other

We are appealing 2 replacement windows that
will not comply w/ St. Paul Egress Policy. Measurements
for existing window is included. There will also
be 1 window in another bedroom that is
an equivalency to the St. Paul Policy.
Please Approve.



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: January 10, 2012

APPEAL PROPERTY ADDRESS: 1389 SCHLETTI ST

APPLICANT NAME: RENEWAL BY ANDERSEN CORPORATION

PHONE NUMBER: 651-264-4914

PERMIT NUMBER: 12 003306

TYPE OF WINDOW Double Hung

NUMBER OF WINDOWS 2

Total Glazed Area Minimum 5 Square Feet	6.3	Difference from Required Area	+1.3
Width of Opening Minimum 20 Inches	24"	Difference from Required Opening	+4
Height of Opening Minimum 24 Inches	19"	Difference from Required Opening	- 5
Height of Opening to Finished Floor Maximum 48 Inches for Existing Openings	<48	Difference from Maximum Height	Ok

COMMENTS:

Reviewed by: