

# **APPLICATION FOR APPEAL**

RECEIVED
NOV 29 2012
CITY CLERK

# Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd. Saint Paul, Minnesota 55102 Telephone: (651) 266-8560

The City Clerk needs the following to proceed	ess your appeal:	
\$25 filing fee payable to the City of Sai (if cash: receipt number) \( \tilde{\cappa} \) (copy of the City-issued orders or letter are being appealed  Attachments you may wish to include This appeal form completed  Walk-In \( OR \) \( \tilde{\cappa} \) Mail-In	ase waive for	YOUR HEARING Date and Time:  Tuesday, 12-4-12  Time 11:30 a.m.  Location of Hearing: Room 330 City Hall/Courthouse
Address Being Appealed:		
Number & Street: 1094 Reaney Ave City: St. Paul State: MN Zip: 55106  Appellant/Applicant: Rearlie Reid - tenant Email 116a. Nollinesworth@ Smr 15.00  Phone Numbers: Business 651-894-6922 Residence Cell  Signature: Malle Lisa Hollingswill Date: 11/29/12		
Name of Owner (if other than Appellant): Renato Otten  Address (if not Appellant's): 291 Addison Rd N, Wood Dale 1L 60191		
Phone Numbers: Business 952-470-8880, Residence Cell		
What Is Being Appealed and Why? Attachments Are Acceptable		
<ul> <li>□ Summary/Vehicle Abatement</li> <li>□ Fire C of O Deficiency List</li> <li>□ Fire C of O: Only Egress Windows</li> </ul>	lacant Buildings the first 4	harded as a Registered  ng on 11/19/2012: This  that the tenent knew  as a problem with  the home.
□ Other		

#### DEPARTMENT OF SAFETY AND INSPECTIONS

Steve Magner, Manager of Code Enforcement



Nuisance Building Code Enforcement 375 Jackson Street, Suite 220 Saint Paul, MN 55101-1806

651-266-8989 651-266-1919 www.stpaul.gov/dsi

November 21, 2012

Renato Otten 1094 Reaney Ave St Paul MN 55106-3919

#### VACANT BUILDING REGISTRATION NOTICE

## The premises at 1094 REANEY AVE

has been inspected and found to meet the legal definition of a Vacant Building as described in Saint Paul Legislative Code, Chapter 43. You are required to register this building with the Department of Safety and Inspections, Vacant Buildings Division, by filling out and returning the registration form provided with this letter. You are also required to pay the annual Vacant Building Registration Fee of \$1,100.00 The fee is due upon receipt of this letter and must be paid no later than thirty (30) days from the date of this letter, as required in Saint Paul Legislative Code Chapter 43. If this building is vacant due to a fire, complete the enclosed registration form and return it to this office within 30 days.

Please return the enclosed registration form along with your payment by December 21, 2012.

## Do not mail cash.

If you wish to pay in person, you may do so from 8:00 a.m. to 4:00 p.m. Monday through Friday at:

DEPARTMENT OF SAFETY AND INSPECTIONS 375 Jackson Street, Suite 220 Saint Paul, MN 55101-1806

You may file an appeal to this fee or registration requirements by contacting the Office of the City Clerk at (651) 266-8688. Any appeal of this fee must be made within ten (10) days of the date of this notice.

If the registration fee is not received in this office within 45 days of the date of this letter the full amount owed will be assessed to, and collected with, the taxes for this property as permitted by Saint Paul Legislative Code Chapter 43.

The Code Enforcement Officer has notified the Building Inspection And Design Section that this property meets the legal definition of a registered vacant building and in accordance with Legislative Code Chapter 33, no permits (except demolition, wrecking and removal permits) will be issued until the requirements of all applicable ordinances are fulfilled.

All category 2 and category 3 vacant buildings must be winterized with gas and water services shut off or, alternately, an excess flow gas valve must be installed in the dwelling, within sixty (60) days of the date of this Notice.

# WRITTEN PERMISSION FROM THE CITY OF SAINT PAUL IS REQUIRED BEFORE A CATEGORY 2 OR CATEGORY 3 VACANT BUILDING CAN BE OCCUPIED OR SOLD.

- Category 2: Requirements include: 1. register/re-register the building, 2. pay outstanding fee(s), 3. obtain a code compliance report, 4. submit for approval a rehab cost estimate from a licensed contractor and a schedule for completion of all code compliance work, 5. submit proof of financial responsibility acceptable to the City, and 6. obtain Zoning approval of the proposed use.
- Category 3: All requirements listed for Category 2 vacant buildings, AND obtain a Certificate of Occupancy OR Certificate of Code Compliance prior to the sale of the building.

If the use of this building meets the definition of a nonconforming use by the Zoning Code then the use will lose its nonconforming status 365 days from the date the building was declared vacant.

You must contact the Enforcement officer, Dave Nelmark, at 651-266-1931 to find out what must be done before this building can be legally reoccupied.

The Enforcement Officer may declare this building(s) to constitute a Nuisance Building subject to demolition and issue an Order to Abate under authority of Legislative Code Chapter 45. In the event this building is declared a Nuisance Building subject to demolition, the Enforcement Officer will notify all owners and interested parties of the Order to Abate, as provided in the Legislative Code Chapter 45.

If you have questions about this annual registration fee or other vacant building requirements, please contact the Enforcement Officer, Dave Nelmark, at 651-266-1931.

This registration form and fee is required by law. Your prompt attention to this matter is appreciated.

Thank You,


Steve Magner Vacant Buildings Program Manager Department of Safety and Inspections

**Enclosures:** 

Regulations Requirements Information Vacant Building Registration Form

SM: dn

vb registration notice 06/10



375 Jackson Street, Suite 220 Saint Paul, Minnesota 55101-1806 

 Telephone:
 651-266-8989

 Facsimile:
 651-266-8951

 Web:
 www.stpaul.gov/dsi

November 1, 2012 RENATO OTTEN 291 ADDISON RD N WOOD DALE IL 60191-1903

# Revocation of Fire Certificate of Occupancy and Order to Vacate

RE:

1094 REANEY AVE

Ref. # 113513

### Dear Property Representative:

And attempt was made to inspect the interior of your building on November 1, 2012, for the renewal of the Certificate of Occupancy. Since you have failed to comply with the applicable requirements, it has become necessary to revoke the Certificate of Occupancy in accordance with Section 40.06 of the Saint Paul Legislative Code. A reinspection will be made on November 15, 2012 to verify that the property is vacated.

The Saint Paul Legislative Code further provides that no building shall be occupied without a Certificate of Occupancy. Failure to immediately complete the following deficiency list or the building vacated may result in a criminal citation.

#### **DEFICIENCY LIST**

- 1. Garage SPLC 34.08 (5), 34.31 (3) Repair, replace and maintain all exterior surfaces on fences, sheds, garages and other accessory structures free from holes and deterioration. Provide and maintain exterior unprotected surfaces painted or protected from the elements.
- 2. SPLC 34.11 (6), 34.34 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
- 3. SPLC 39.02(c) Complete and sign the smoke detector affidavit and return it to this office.
- 4. MSFC 304.1 Remove excessive combustible storage and/or vegetation from exterior property areas.