



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-80

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 4/4/2012

Title: Appeal of Ronald D. Juelfs to a Fire Certificate of Occupancy Correction Notice at 1142 FOREST STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1142 Forest.appeal.2-21-12, 2. 1142 Forest St.Juelfs Ltr 3-5-12.pdf

Date	Ver.	Action By	Action	Result
4/10/2012	2	Mayor's Office	Signed	
4/4/2012	2	City Council	Adopted	Pass
2/28/2012	1	Legislative Hearings	Referred	

Appeal of Ronald D. Juelfs to a Fire Certificate of Occupancy Correction Notice at 1142 FOREST STREET.

None indicated

February 17, 2012

Mike Cassidy

No hearing necessary.

Yes, north bedroom - 7 inches egress opening height; south bedroom - 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Ronald D. Juelfs to a Fire Certificate of Occupancy Correction Notice at 1142 FOREST STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance in the egress opening height for the window in the north bedroom and a 3-inch variance of the egress window opening height of the window in the south bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.