



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-77

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 4/4/2012

Title: Appeal of Brad Leventhal to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 441 GRAND AVENUE.

Sponsors: Dave Thune

Indexes: Fire C of O Letter, Ward - 2, Windows

Code sections:

Attachments: 1. 441 Grand.appeal.2-17-12.pdf, 2. 441 Grand Ave.Leventhal Ltr 3-5-12.pdf, 3. 441 Grand Ave.Owner Photos

Date	Ver.	Action By	Action	Result
4/10/2012	2	Mayor's Office	Signed	
4/4/2012	2	City Council	Adopted	Pass
2/28/2012	1	Legislative Hearings	Referred	

Appeal of Brad Leventhal to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 441 GRAND AVENUE.

Units 1 & 2 have egress windows with ladders permanently affixed to the wall. Unit 1 is 12 inches from sill. Unit 2 is 42 inches. Request was made to replace with steps 48 inches from sill. We would like keep the ladders, which are closer to sill, allowing easier exit. Units 1, 3, and 5 have double hung windows with openings of 20 inches high X 29.5 inches wide (4.92 sq. ft. opening).

January 27, 2012

William Beumer

Hearing necessary on Unit 1 north and unit 2 bedroom egress window sill heights.

Yes, Unit 1 south bedroom - 6.5 inches egress opening height; unit 3 and 5 south bedroom - 6.5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Brad Leventhal to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 441 GRAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6.5-inch variance on the openable height of the egress windows in Unit 1 south bedroom and Units 3 and 5 south bedrooms; and grant the minimum sill height for Unit 1 north bedroom and Unit 2 bedroom on the condition that four handholds are installed on each side of the ladders ; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's

recommendation in this matter.