



## Legislation Details (With Text)

**File #:** RLH FCO 12- **Version:** 2  
159

**Type:** Resolution LH Fire C of O OR **Status:** Passed  
Correction Order

**In control:** City Council

**Final action:** 4/4/2012

**Title:** Appeal of Jason Koenig to a Fire Certificate of Occupancy Inspection Correction Notice at 1391 STANFORD AVENUE.

**Sponsors:** Chris Tolbert

**Indexes:** Fire C of O Letter, Ward - 3, Windows

**Code sections:**

**Attachments:** 1. 1391 Stanford.appeal.3-2-12, 2. 1391 Standford Ave.Koenig Ltr 3-15-12

Date	Ver.	Action By	Action	Result
4/10/2012	2	Mayor's Office	Signed	
4/4/2012	2	City Council	Adopted	Pass
3/13/2012	1	Legislative Hearings	Referred	

Appeal of Jason Koenig to a Fire Certificate of Occupancy Inspection Correction Notice at 1391 STANFORD AVENUE.

1. Back Stairway - Like to completely replace. Will pull permit & do, however like extension for better weather.
4. Escape Window too small - Would like exception to maintain integrity of home.
5. Garage - Extension due to weather.  
(paraphrased)

February 22, 2012

Rick Gavin

Hearing necessary on balance of appeal.

Yes, 6.5 inches egress opening height for lower unit.

WHEREAS, in the matter of the Appeal of Jason Koenig to a Fire Certificate of Occupancy Inspection Correction Notice at 1391 STANFORD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant an extension to May 1, 2012 for compliance on the back stairway upper unit and painting of the garage; and grant a 6.5-inch variance on the openable height of the egress window in the upper unit bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

