



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
249

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 12/21/2011

Title: Appeal of David Kendrick to a Fire Certificate of Occupancy Inspection Correction Notice at 771 NEBRASKA AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 771 Nebraska.appeal.11-21-11.pdf, 2. 771 Nebraska Ave E.Kendrick Ltr 12-5-11.pdf

Date	Ver.	Action By	Action	Result
12/29/2011	2	Mayor's Office	Signed	
12/21/2011	2	City Council	Adopted	Pass
12/6/2011	1	Legislative Hearings	Referred	

Appeal of David Kendrick to a Fire Certificate of Occupancy Inspection Correction Notice at 771 NEBRASKA AVENUE EAST.

Only egress windows

November 15, 2011

Mike Cassidy

No hearing necessary.

Yes, 4 inches for egress opening heights.

WHEREAS, in the matter of the Appeal of David Kendrick to a Fire Certificate of Occupancy Inspection Correction Notice at 771 NEBRASKA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in the northwest and south bedrooms, and grant a 4-inch variance on the openable height of the egress window in the southwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.