



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-123

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 5/2/2012

Title: Appeal of Wendy Smith to a Fire Certificate of Occupancy Inspection Correction Notice at 599 SHERWOOD AVENUE.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 599 Sherwood.appeal.4-3-12.pdf, 2. 599 Sherwood Ave.Smith Ltr 4-13-12.pdf

Date	Ver.	Action By	Action	Result
5/7/2012	2	Mayor's Office	Signed	
5/2/2012	2	City Council	Adopted	Pass
4/10/2012	1	Legislative Hearings	Referred	

Appeal of Wendy Smith to a Fire Certificate of Occupancy Inspection Correction Notice at 599 SHERWOOD AVENUE.

Only egress windows

March 27, 2012

Mike Cassidy

No hearing necessary.

Yes, 3 inches egress opening height. Orders were not necessary on windows of these dimensions.

WHEREAS, in the matter of Appeal of Wendy Smith to a Fire Certificate of Occupancy Inspection Correction Notice at 599 SHERWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance in the egress window opening height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.