



## Legislation Details (With Text)

**File #:** RLH WP 12- 10 **Version:** 3  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 2/15/2012  
**Title:** Appeal of Daniel Schmidt, on behalf of Saint Paul Ramsey County Department of Public Health, to two Egress Window Non-Compliance Determinations at 1699 CASE AVENUE.  
**Sponsors:** Dan Bostrom  
**Indexes:** Ward - 6, Windows  
**Code sections:**  
**Attachments:** 1. 1699 Case.appeal.1-17-12.pdf, 2. 1699 Case Ave.Public Health REVISED Ltr.1-26-12.pdf

Date	Ver.	Action By	Action	Result
2/21/2012	3	Mayor's Office	Signed	
2/15/2012	3	City Council	Adopted	Pass
1/24/2012	2	Legislative Hearings	Referred	

Appeal of Daniel Schmidt, on behalf of Saint Paul Ramsey County Department of Public Health, to two Egress Window Non-Compliance Determinations at 1699 CASE AVENUE.

(Windows)

January 16, 2012

(none listed)

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Saint Paul Ramsey County Department of Public Health, to two Egress Window Non-Compliance Determinations at 1699 CASE AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 23.3 inches wide, and grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20 inches high by 26.8 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.