



## Legislation Details (With Text)

**File #:** RLH FCO 12- **Version:** 2  
652

**Type:** Resolution LH Fire C of O OR **Status:** Passed  
Correction Order

**In control:** City Council

**Final action:** 2/20/2013

**Title:** Appeal of Matt Connelly to a Fire Inspection Correction Notice at 1966 BENSON AVENUE.

**Sponsors:** Dave Thune

**Indexes:** Fire C of O Letter, Ward - 2

**Code sections:**

**Attachments:** 1. 1966 Benson Ave.appeal.12-11-12, 2. 1966 Benson Ave.Inspector Email.12-20-12, 3. 1966 Benson Ave.1997-9 Inspection Reports, 4. 1966 Benson Ave.Connelly & Amidon Ltr 12-20-12, 5. 1966 Benson Ave.Owner Email with Photos.12-26-12, 6. 1966 Benson Ave.Photos.12-27-12, 7. 1966 Benson Ave.Photo 2 .12-27-12, 8. 1966 Benson Ave.Photo 3 .12-27-12, 9. 1966 Benson Ave.Amidon Ltr 1-23-13, 10. 1966 Benson Ave.Amidon Revised Ltr 1-23-13, 11. Amidon Graphics - Appeal of Storage Height Variance

Date	Ver.	Action By	Action	Result
2/25/2013	2	Mayor's Office	Signed	
2/20/2013	2	City Council	Adopted As Amended	Pass
2/6/2013	2	City Council	Continue Public Hearing	Pass
1/15/2013	2	Legislative Hearings	Referred	
12/18/2012	1	Legislative Hearings	Laid Over	

Appeal of Matt Connelly to a Fire Inspection Correction Notice at 1966 BENSON AVENUE.

Roll storage from 12 feet to 16 feet.

December 6, 2012

Mitchell Imbertson

### **AMENDED 2/20/13**

WHEREAS, in the matter of the Appeal of Matt Connelly to a Fire Inspection Correction Notice at 1966 BENSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a storage height variance of 2 feet, allowing that the paper rolls may be stored to a height of 14 feet, with a deadline for compliance of March 1, 2013; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby ~~accepts and adopts the Legislative Hearing Officer's recommendation in this matter~~ grants the appeal.

