



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-100

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 4/18/2012

Title: Appeal of Terry Heim to a Fire Certificate of Occupancy Inspection Correction Notice at 1374 MCLEAN AVENUE.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7, Windows

Code sections:

Attachments: 1. 1374 Mclean.appeal.3-9-12.pdf, 2. 1374 Mclean Ave.Heim I Ltr 3-22-12.pdf

Date	Ver.	Action By	Action	Result
4/25/2012	2	Mayor's Office	Signed	
4/18/2012	2	City Council	Adopted	
3/20/2012	1	Legislative Hearings	Referred	

Appeal of Terry Heim to a Fire Certificate of Occupancy Inspection Correction Notice at 1374 MCLEAN AVENUE.

House built in 1977. Windows in good working order. Plenty of egress.

February 28, 2012

Wayne Spiering

No hearing necessary.

Yes, both units - 3 inches egress opening height.

WHEREAS, in the matter of the Appeal of Terry Heim to a Fire Certificate of Occupancy Inspection Correction Notice at 1374 MCLEAN AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress windows in the lower unit northwest and southwest bedrooms and upper unit northwest and southwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.