



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: ALH 11-336, **Version:** 1

Appeal of Susan Rosas to a Fire Inspection Correction Notice at 2212 FOURTH STREET EAST.

Would like a variance for the upper bedroom window.

20h X 25w - openable

41h X 24w - glazed

February 10, 2011

No hearing Necessary. Recommend variance on egress window dimensions.