



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH FCO 20-168, **Version:** 2

Appeal of Irine Katras to a Fire Inspection Correction Notice at 1676 WHITE BEAR AVENUE NORTH.

WHEREAS, in the matter of Appeal of Irine Katras to a Fire Inspection Correction Notice at 1676 WHITE BEAR AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council 1) grant to March 31, 2021 for installation of stainless steel side panels over grill hood and installation of additional nozzles in fire suppression system; and 2) grant to July 1, 2022 for compliance with orders as they relate to gyro machine. All Interim safety measures, such as turning off machine when not in use and cleaning grease out hourly shall remain in place, and a fire extinguisher must be within 8 feet of machine at all times; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.