



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-235, **Version:** 2

---

Appeal of Scott Spiess to a Fire Inspection Correction Notice (windows only) at 1412 TAYLOR AVENUE.

Short by 4 inches with 27 inches wide, 6.7 sq. ft. total.

May 23, 2012

Mitchell Imbertson

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Scott Spiess to a Fire Inspection Correction Notice (windows only) at 1412 TAYLOR AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress window in the second floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.