



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FOW 12-95, **Version:** 2

---

Appeal of Saint Paul Public Housing Agency to a Fire Certificate of Occupancy Inspection Correction Notice at 434 HOYT AVENUE EAST.

#4 northeast and northwest bedrooms - Request variance on openable height.

February 8, 2012

Mike Cassidy

Hearing required, unless appellant can demonstrate window opens to at least 16 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Saint Paul Public Housing Agency to a Fire Certificate of Occupancy Inspection Correction Notice at 434 HOYT AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance egress opening height for the northeast and northwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.