



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-35

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 2/15/2012

Title: Appeal of Jackie Visnovec to a Correction Notice-Complaint Inspection at 1720 ASHLAND AVENUE.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4, Windows

Code sections:

Attachments: 1. 1720 Ashland.appeal.1-13-12.pdf, 2. 1720 Ashland Ave.Visnovec Ltr.1-26-12.pdf

Date	Ver.	Action By	Action	Result
2/21/2012	2	Mayor's Office	Signed	
2/15/2012	2	City Council	Adopted	Pass
1/24/2012	1	Legislative Hearings	Referred	

Appeal of Jackie Visnovec to a Correction Notice-Complaint Inspection at 1720 ASHLAND AVENUE.

All current upper level egress windows have a half inch shortage in height but have an excess of nine and a half inches in width.

The basement apartment window has a one inch shortage in width but has an excess of twelve inches in height.

These windows work extremely effectively if a person needed a quick exit.

January 11, 2012

Leanna Shaff

No hearing necessary.

Appellant should be called about time of hearing if a window variance is not granted. -rrn

Yes, 0.5 inch variance in egress opening height of all units. Also, 1 inch variance egress opening width of basement casement window.

WHEREAS, in the matter of the Appeal of Jackie Visnovec to a Correction Notice-Complaint Inspection at 1720 ASHLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable width of the egress window in the basement unit bedroom and a .5-inch variance on the openable height of the egress windows in all other units; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

