

Legislation Details (With Text)

| File #: | RLH FOW 12-30 | Version: 2 | | | | |
|----------------|--|------------|---------------|--------------|--|--|
| Туре: | Resolution LH Fire Ordered Windows | | Status: | Passed | | |
| | | | In control: | City Council | | |
| | | | Final action: | 2/15/2012 | | |
| Title: | Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 936 BARCLAY STREET. | | | | | |
| Sponsors: | Dan Bostrom | | | | | |
| Indexes: | Correction Order, Ward - 6, Windows | | | | | |
| Code sections: | | | | | | |

Attachments: 1. 936 Barclay.appeal.1-12-12.pdf, 2. 936 Barclay St.Swanson Ltr.1-26-12.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 2/21/2012 | 2 | Mayor's Office | Signed | |
| 2/15/2012 | 2 | City Council | Adopted | Pass |
| 1/24/2012 | 1 | Legislative Hearings | Referred | |

Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 936 BARCLAY STREET.

#3 - Request variance on openable height.

December 28, 2012

James Thomas

Hearing necessary.

WHEREAS, in the matter of the Appeal of Tony Swanson, on behalf of Public Housing Agency of St. Paul, to a Fire Certificate of Occupancy Correction Notice at 936 BARCLAY STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of the egress bedroom window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.