



## Legislation Details (With Text)

**File #:** RLH WP 12-8 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 3/7/2012  
**Title:** Appeal of Ronald Drexl to an Egress Window Non-Compliance Determination at 998 RANDOLPH AVENUE.  
**Sponsors:** Dave Thune  
**Indexes:** Ward - 2, Windows  
**Code sections:**  
**Attachments:** 1. 998 Randolph.appeal.1-17-12.pdf, 2. 998 Randolph Ave.Drexl Ltr.1-27-12.pdf

Date	Ver.	Action By	Action	Result
3/13/2012	2	Mayor's Office	Signed	
3/7/2012	2	City Council	Adopted	Pass
1/24/2012	1	Legislative Hearings	Referred	

Appeal of Ronald Drexl to an Egress Window Non-Compliance Determination at 998 RANDOLPH AVENUE.

See attached form/need to get variance

January 12, 2012

David Tank

No hearing necessary.

Yes, 2.5 inches egress opening width.

WHEREAS, in the matter of the Appeal of Ronald Drexl to an Egress Window Non-Compliance Determination at 998 RANDOLPH AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable width of one slider replacement egress bedroom window measuring 17.5 inches wide by 42 inches high; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.