



Legislation Details (With Text)

File #: RLH FOW 12-85 **Version:** 2
Type: Resolution LH Fire Ordered Windows **Status:** Passed
In control: City Council
Final action: 4/4/2012
Title: Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 1222 DESOTO STREET.
Sponsors: Amy Brendmoen
Indexes: Fire C of O Letter, Ward - 5, Windows
Code sections:

Attachments: 1. 1222 Desoto.appeal.2-24-12.pdf, 2. Egress Windows - PHA letter, 3-6-12 Hrg - 3-9-12.pdf, 3. Egress Windows - PHA Revsied letter, 3-6-12 Hrg - 3-9-12.pdf

Date	Ver.	Action By	Action	Result
4/10/2012	2	Mayor's Office	Signed	
4/4/2012	2	City Council	Adopted	Pass
3/6/2012	1	Legislative Hearings	Referred	

Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 1222 DESOTO STREET.

#3 Southeast and northeast bedroom - Request variance on openable width.

#4 Southwest bedroom - Request variance on openable height.

February 6, 2012

Mike Cassidy

No hearing necessary.

Yes, southeast and northeast bedrooms - 1 inch egress opening width and southwest bedroom - 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Tony Swanson, Saint Paul Public Housing Agency, to a Fire Certificate of Occupancy Inspection Correction Notice at 1222 DESOTO STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable width of the egress windows in the southeast and northeast bedrooms, and grant a 5-inch variance on the openable height of the egress window in the southwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.