



## Legislation Details (With Text)

**File #:** RLH WP 12- 26 **Version:** 2

**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 4/18/2012

**Title:** Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1108 SIXTH STREET EAST.

**Sponsors:** Kathy Lantry

**Indexes:** Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 1108 6th.appeal.3-12-12.pdf, 2. 1108 6th St.Public Health Ltr 3-22-12

Date	Ver.	Action By	Action	Result
4/25/2012	2	Mayor's Office	Signed	
4/18/2012	2	City Council	Adopted	
3/20/2012	1	Legislative Hearings	Referred	

Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1108 SIXTH STREET EAST.

(2 windows)

January 26, 2012

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the the Appeal of Daniel Schmidt, Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 1108 SIXTH STREET EAST; Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19 inches high by 23 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.