



Legislation Details (With Text)

File #: RLH FOW 12-120 **Version:** 2

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 5/2/2012

Title: Appeal of Lori Kustritz, oh behalf of EMK Holding Company, to a Correction Notice - Complaint Inspection at 1191 RICE STREET.

Sponsors: Amy Brendmoen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 1191 Rice.appeal.3-30-12, 2. 1191 Rice St.Kustritz Ltr 4-13-12.pdf

Date	Ver.	Action By	Action	Result
5/7/2012	2	Mayor's Office	Signed	
5/2/2012	2	City Council	Adopted	Pass
4/10/2012	1	Legislative Hearings	Referred	

Appeal of Lori Kustritz, oh behalf of EMK Holding Company, to a Correction Notice - Complaint Inspection at 1191 RICE STREET.

2nd appeal. 1st measurement wasnot accurate (Lisa Martin measured 15 x 24). Leanna S. measured it @ 17 x 25.5.

March 28, 2012

Leanna Shaff

No hearing necessary.

Yes, 7 inches egress opening height.

WHEREAS, in the matter of the Appeal of Lori Kustritz to a Correction Notice - Complaint Inspection at 1191 RICE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance in egress window opening height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.