



## Legislation Details (With Text)

**File #:** RLH FCO 20- 168 **Version:** 2  
**Type:** Resolution LH Fire C of O OR Correction Order **Status:** Passed  
**In control:** City Council  
**Final action:** 2/17/2021  
**Title:** Appeal of Irine Katras to a Fire Inspection Correction Notice at 1676 WHITE BEAR AVENUE NORTH.  
**Sponsors:** Nelsie Yang  
**Indexes:** Fire C of O Letter, Ward - 6  
**Code sections:**

**Attachments:** 1. 1676 White Bear Ave. N.appeal.12-2-2020, 2. 1676 White Bear Ave.photo.6-28-18, 3. 1676 White Bear Ave.Katras Ltr.12-11-20, 4. 1676 White Bear Ave.MN Mech Code.12-2-20.pdf, 5. 1676 White Bear Ave.Photos.12-2-20.pdf, 6. 1676 White Bear Ave.Red Tag.12-2-20.pdf, 7. 1676 White Bear Ave.Katras Ltr.12-23-20, 8. 1676 White Bear Ave.Bids.1-12-21, 9. 1676 White Bear Ave.Katras Ltr.1-15-21, 10. 1676 White Bear Ave N.email.pdf, 11. 1676 White Bear Ave N.Wiese email.pdf, 12. 1676 White Bear Ave N.Reisberg email.pdf, 13. 1676 White Bear Ave.Katras Ltr.2-5-21, 14. 1676 White Bear Ave.Katras email and photos.3-18-21

Date	Ver.	Action By	Action	Result
2/19/2021	2	Mayor's Office	Signed	
2/17/2021	2	City Council	Adopted	Pass
2/2/2021	1	Legislative Hearings	Referred	
1/12/2021	1	Legislative Hearings	Laid Over	
12/22/2020	1	Legislative Hearings	Laid Over	
12/8/2020	1	Legislative Hearings	Laid Over	

Appeal of Irine Katras to a Fire Inspection Correction Notice at 1676 WHITE BEAR AVENUE NORTH.

WHEREAS, in the matter of Appeal of Irine Katras to a Fire Inspection Correction Notice at 1676 WHITE BEAR AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council 1) grant to March 31, 2021 for installation of stainless steel side panels over grill hood and installation of additional nozzles in fire suppression system; and 2) grant to July 1, 2022 for compliance with orders as they relate to gyro machine. All Interim safety measures, such as turning off machine when not in use and cleaning grease out hourly shall remain in place, and a fire extinguisher must be within 8 feet of machine at all times; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.