



## Legislation Details (With Text)

**File #:** RLH WP 11- 77 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 11/2/2011  
**Title:** Appeal of Saint Paul Ramsey County Department of Public Health, on behalf of True Hang and Suenie Yang, to an Egress Window Non-Compliance Determination at 945 EDMUND AVENUE.  
**Sponsors:** Melvin Carter III  
**Indexes:** Ward - 1, Windows  
**Code sections:**  
**Attachments:** 1. 945 Edmund.appeal.9-23-11.pdf, 2. 945 Edmund Ave.Schmidt Ltr 10-13-11.pdf

Date	Ver.	Action By	Action	Result
11/9/2011	2	Mayor's Office	Signed	
11/2/2011	2	City Council	Adopted	Pass
10/11/2011	1	Legislative Hearings	Referred	

Appeal of Saint Paul Ramsey County Department of Public Health, on behalf of True Hang and Suenie Yang, to an Egress Window Non-Compliance Determination at 945 EDMUND AVENUE.

(4 windows)

September 23, 2011

Yes, 2 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Saint Paul Ramsey County Department of Public Health to an Egress Window Non-Compliance Determination at 945 EDMUND AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of four double-hung replacement egress bedroom windows measuring 22 inches high by 23.3 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.