



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
213

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 11/16/2011

Title: Appeal of Zaw Wai to a Fire Certificate of Occupancy Correction Notice at 933 FIFTH STREET EAST.

Sponsors: Kathy Lantry

Indexes: Ward - 7, Windows

Code sections:

Attachments: 1. 933 Fifth Street.appeal.10-14-11.pdf, 2. 933 5th St E.Wai PC ltr 11-3-11.pdf

Date	Ver.	Action By	Action	Result
11/22/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/25/2011	1	Legislative Hearings	Referred	

Appeal of Zaw Wai to a Fire Certificate of Occupancy Correction Notice at 933 FIFTH STREET EAST.

October 3, 2011

Yes - 5 inch variance in egress opening height of south bedroom window and 2 inch variance in egress opening height of north bedroom window. No hearing necessary.

WHEREAS, in the matter of the Appeal of Zaw Wai to a Fire Certificate of Occupancy Correction Notice at 933 FIFTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable height of four double hung replacement egress bedroom windows measuring 22.5 inches high by 28 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.