



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH WP 12-8, **Version:** 2

---

Appeal of Ronald Drexl to an Egress Window Non-Compliance Determination at 998 RANDOLPH AVENUE.

See attached form/need to get variance

January 12, 2012

David Tank

No hearing necessary.

Yes, 2.5 inches egress opening width.

WHEREAS, in the matter of the Appeal of Ronald Drexl to an Egress Window Non-Compliance Determination at 998 RANDOLPH AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable width of one slider replacement egress bedroom window measuring 17.5 inches wide by 42 inches high; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.