



Legislation Text

File #: RLH WP 12-28, **Version:** 2

Appeal of Renewal by Andersen, on behalf of Marie Dotseth, to an Egress Window Non-Compliance Determination at 812 FAIRMOUNT AVENUE.

We are replacing 2 windows that will not comply w/egress policy. Openings will be short in openable height by 4-7/8". The homeowners want to keep style consistent throughout the home. All windows in home are being proposed for replacement. Please approve.

March 23, 2012

DD

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Renewal by Andersen, on behalf of Marie Dotseth, to an Egress Window Non-Compliance Determination at 812 FAIRMOUNT AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance in the egress opening height of the appealed window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.