



CITY OF SAINT PAUL
OFFICE OF THE CITY COUNCIL
310 CITY HALL
15 WEST KELLOGG BOULEVARD
SAINT PAUL, MN 55102-1615
Marcia Moermond, Legislative Hearing Officer
EMAIL: legislativehearings@ci.stpaul.mn.us
PHONE: (651) 266-8585 FAX: (651) 266-8574

November 9, 2022

Frank Viggiano
Viggco, LLC
86 Spruce Street
Mahtomedi, MN 55115

VIA EMAIL: fviggiano@comcast.net

Re: Remove or Repair of the Structure(s) at 575 Park Street

Dear Mr. Viggiano:

This email is to confirm that today at the Legislative Hearing on Tuesday, November 8, 2022 the matter was continued to Legislative Hearing on **Tuesday, November 22 at 10:00 am for further discussion and update from owner and/or contractors on outstanding items to complete the project.**

Per my October 5 email the following items still need to be addressed:

- chimney liner required
- vent clothes dryer to code
- provide adequate combustion air

Let me know if you have questions, I can be reached at 651-266-8515.

Sincerely,

/s/

Joanna Zimny
Legislative Hearing Executive Assistant

- c: Rehabilitation & Removal staff
Steve Magner – Department of Safety & Inspections, Housing and Code Enforcement Manager
Hector Flores via email: h.a1contractorsllc@gmail.com
John Flores via email : alamominn@gmail.com
Haley Cobb via email: cobbhaley@gmail.com