



August 9, 2022

ANGELA DUBOSE
PO BOX 13101
ST PAUL MN 55414 USA

CORRECTION NOTICE - RE-INSPECTION COMPLAINT

RE: 619 MENDOTA ST
Ref. # 107056

Dear Property Representative:

A re-inspection was made on your building on August 9, 2022, in response to a complaint. You are hereby notified that the following deficiencies must be corrected prior to re-inspection date. A reinspection will be made on August 31, 2022 .

Failure to comply may result in a criminal citation or the revocation of the Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Certificate of Occupancy. The code also provides for the assessment of additional reinspection fees.

DEFICIENCY LIST

1. Unit 2 - SPLC 34.10 (1), 34.34 (4), 34.16 - Provide and maintain interior in a clean and sanitary condition.-
2. Unit 2 - SPLC 34.09 (4), 34.33 (3) -All screens shall be maintained in a professional state of maintenance and repair.-
3. Unit 2 - SPLC 34.12 (2), SPLC 34.36 (1) - Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.-

4. MSFC 304.1 - Remove excessive combustible storage and/or vegetation from exterior property areas.-
5. SPLC 34.09 (1)(2)(a), 34.33 (1)(b) - Provide and maintain all exterior walls free from holes and deterioration. All wood exterior unprotected surfaces must be painted or protected from the elements and maintained in a professional manner free from chipped or peeling paint.- PERMITS REQUIRED FOR THIS WORK.
6. SPLC 34.09 (4) a, 34.33 (3) a - Repair and maintain the window glass. Windows shall be fully supplied with windowpanes which are without open cracks or holes.-
7. SPLC 34.09 (4), 34.33 (3) - Repair and maintain the window frame.-
8. SPLC 34.09 (4), 34.33 (3) -All screens shall be maintained in a professional state of maintenance and repair.-
9. SPLC 34.23, MSFC 111.1 - This occupancy is condemned as unsafe AND dangerous. This occupancy must not be used until re-inspected and approved by this office.-

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: 651-266-8585 and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 a.m. - 9:00 a.m.

Please help to make Saint Paul a safer city in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector

An Equal Opportunity Employer

Ref. # 107056