



November 21, 2022
Charles Forest

523 180TH ST
OSCEOLA WI 54020USA

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 995 BURNS AVE
Ref. # 107838

Dear Property Representative:

Your building was determined to be a registered vacant building on October 21, 2022. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

DEFICIENCY LIST

1. Attic - SPLC 34.10 (3), 34.34(2) - Provide an approved handrail. Every required handrail and guard shall be firmly fastened and capable of supporting imposed loads and shall be maintained in a professional state of maintenance and repair and in accordance with the building code in effect at the time of construction or as altered/modified under an approved building permit.-
2. Unit 1 - MSFC SECTION - 305 .4 - DELIBERATE OR NEGLIGENT BURNING It shall be unlawful to deliberately or through negligence set fire to or cause the burning of combustible material in such a manner as to endanger the safety of persons or property- You are burning incense in a wood container - discontinue this use of burning incense. Use a metal tray.
3. Unit 1 - Bedroom West side - MSFC 604.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.-

4. Unit 1 - MSFC 603.6 - Have the chimneys, fireplaces, and vents inspected for soundness, freedom from deposits, and correct clearances. Cleaning, maintenance, and repairs shall be done if indicated by the inspection.-

5. Unit 1 - SPLC 34.11 (1), MSBC 2902.1, SPLC 34.35 (1), MPC 301.1 - Repair or replace and maintain all parts of the plumbing system to an operational condition.-Repair or replace and maintain an approved private toilet. Secure toilet in place.

6. SPLC 39.02(c) - Complete and sign the smoke alarm affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: <http://www.stpaul.gov/cofo>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: james.thomas@ci.stpaul.mn.us or call me at 651-266-8983 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

James Thomas
Fire Safety Inspector

Ref. # 107838