



CITY OF SAINT PAUL

Code Compliance Report

October 20, 2021

*** * This Report must be Posted
on the Job Site * ***

TYCOON IMMOBILIERS LLC
869 SWAPS DRIVE
SHAKOPEE MN 55379

Re: 802 Mound St
File#: 20 027429 VB2

Dear Property Owner:

The following is the Code Compliance report you requested on June 11, 2021.

Please be advised that this report is accurate and correct as of the date October 20, 2021. All deficiencies identified by the City after this date must also be corrected and all codes and ordinances must be complied with. This report is valid for 365 days from October 20, 2021. This report may be used in lieu of a Truth in Housing Report required in St Paul Legislative Code 189. This building must be properly secured and the property maintained at all times.

In order to sell or reoccupy this property the following deficiencies must be corrected. A Legislative Code exemption (Chapter 33.03(f)) allows a Category 2 Vacant Building to be sold "as is" providing the buyer, prior to closing, completes an approval process. For further information, call Reid Soley at 651-266-9120.

ZONING

1. This property is in a(n) R4 zoning district.
2. This property was inspected as a Single Family Dwelling.

BUILDING Inspector: Nathan Bruhn

Phone: 651-266-9033

1. Insure basement cellar floor is even, is cleanable, and all holes are filled. SPLC 34.10 (1)
2. Weather seal exterior doors, threshold and weather-stripping. SPLC 34.09 (3f)
3. Install floor covering in bathroom and kitchen that is impervious to water. SPLC 34.10 (4)
4. Repair walls, ceiling and floors throughout, as necessary. SPLC 34.34 (6)

5. Prepare and paint interior and exterior as necessary. Observe necessary abatement procedures (EPA, MPCA and St. Paul Legislative Code, Chapter 34 for additional information) if lead base paint is present. SPLC 34.33 (1)
6. Air-seal and insulate attic/access door. MN Energy Code Ch 1322.1102.4
7. Install Smoke Detectors/Carbon Monoxide Detectors per MN Conservation Code and the MN Dept. of Labor and Industry: Install per code where feasible. MNRC Ch 1309 Sect 313.2.1
8. Provide major clean-up of premises. SPLC 34.34 (4)
9. Verify proper venting of bath exhaust fan to exterior. SPLC 34.14 (3)
10. Repair siding, soffit, fascia, trim, etc. as necessary. SPLC 34.09 (1)
11. Provide proper drainage around house to direct water away from foundation of house. SPLC 34.08 (2)
12. Dry out basement and eliminate source of moisture. SPLC 34.10 (10)
13. Install downspouts and a complete gutter system. SPLC 34.33 (1d)
14. Replace house and garage roof covering and vents to code. SPLC 34.09 (1)
15. Install flashing in an approved manner at the intersection of the roof with walls, chimneys, and other conjoined surfaces. SPLC 34.09 (1)
16. Remove deck from rear of property and replace to code.
17. Remove all wall paneling in the basement.
18. Insulate attic space.
19. Remove mold, mildew and moldy or water damaged materials. SPLC 34.10 (1)
20. Install handrails (34 inches - 38 inches above each nosing) and guardrails (36 inch minimum) at all stairways, and return hand rail ends into a newel post or wall per attachment. MNRC Ch 1309 Sect. 311 & 312
21. Repair or Replace any deteriorated window sash, broken glass, sash holders, re-putty, etc as necessary. SPLC 34.09 (3)
22. Provide complete storms and screens, in good repair for all door and window openings. SPLC 34.09 (3e)
23. Provide functional hardware at all doors and windows. SPLC 34.09 (3f)
24. Exit doors shall be capable of being opened from the inside, easily and without the use of a key. Remove all surface bolts. SPLC 34.09 (3h)
25. Repair or replace damaged doors and frames as necessary, including storm doors. SPLC 34.09 (3f)
26. A building permit is required to correct the above deficiencies. All work is to be done in a workmanship like manner. SPLC 33.03 (a)

ELECTRICAL Inspector: Randy Klossner

Phone: 651-266-9032

1. Ensure/rewire all electrical associated with NM cables dated after January 2000 to current NEC. An electrical permit was never purchased for that wiring. SPLC 33.03 (d)
2. Check all receptacles for proper polarity (including 2-prong) and verify ground on 3-prong receptacles. Ensure all GFCI receptacles are functioning properly. Rewire and/or replace receptacles that are improperly wired or not functioning

- properly. Article 406.4(D), NEC
3. Install box extensions on devices mounted in wood paneling. Article 314.20, NEC
 4. Remove and/or rewire all illegal, improper or hazardous wiring to current NEC.
 5. Provide proper clearance for overhead service conductors.
 6. No power at time of inspection. Test all electrical outlets and ensure all luminaires (light fixtures) are working properly when power is restored.
 7. Repair the electrical service grounding conductor to the metallic water piping system. Install a conductor sized to Table 250.66 (NEC) from the electrical service to within 5' of the entrance point of the water service, and bond around the water meter. Article 250, NEC
 8. Provide a complete circuit directory at service panel indicating location and use of all circuits. Article 408.4, NEC
 9. Verify that fuse/circuit breaker amperage matches wire size in panel. Replace improperly sized overcurrent devices. Article 240.4, NEC
 10. Close openings in service panel/junction boxes with knockout seals, breaker blanks, proper cable clamps, and/or junction box covers. Article 110.12 (A), NEC
 11. Properly strap and support cables and/or conduits. Chapter 3, NEC
 12. Remove all cord wiring used as a substitute for fixed wiring. Article 400.8, NEC
 13. Repair or replace all broken, painted over, corroded, missing or loose receptacles, luminaires (light fixtures), switches, covers and plates to current code. Article 406.4(D) & Article 410, NEC
 14. All electrical work must be done by a Minnesota-licensed electrical contractor under an electrical permit.

PLUMBING Inspector: Paul Zellmer

Phone: 651-266-9048

1. Basement -Gas Piping -(MFGC 614.1-614.7) Vent clothes dryer to code.
2. Basement -Gas Piping -(MFGC 411) Install an approved shut off; connector and gas piping for the dryer.
3. Basement -Laundry Tub -(MPC 301.1) Repair/replace the faucet that is missing, broken or has parts missing.
4. Basement -Laundry Tub -(MPC .0100 P & Q & 419.2) Install the water piping to code.
5. Basement -Laundry Tub -(MPC 701) Install the waste piping to code.
6. Basement -Plumbing - General -(MPC .0101 Subp. 6) Remove all unused waste, vent, water and gas piping to the main and cap or plug to code.
7. Basement -Soil and Waste Piping -(MPC .0100 M) Replace all corroded cast iron, steel waste or vent piping.
8. Basement -Soil and Waste Piping -(MPC 704 & 706) Replace all improper connections, transitions, fittings or pipe usage.
9. Basement -Soil and Waste Piping -(MPC .0100 L & M & 708.1) Plug all open piping and properly pitch all piping.
10. Basement -Water Heater -(MPC .0100 Q)The water heater must be fired and in service.

11. Basement -Water Heater -(MPC 501)Install the water piping for the water heater to code.
12. Basement -Water Heater -(MFGC 501.12) The water heater venting requires a chimney liner.
13. Basement -Water Heater -(MFGC 409) Install the gas shut off and the gas piping to code.
14. Basement -Water Heater -(MPC 507.5) Correct the pressure and temperature relief valve discharge.
15. Basement -Water Meter -(MPC 606.2) The service valves must be functional and installed to code.
16. Basement -Water Meter -(MPC 609.11) Support the water meter to code.
17. Basement -Water Meter -(MPC 609.11 & SPRW Sec. 904.04 (a))Raise the water meter to a minimum of 12 inches above the floor.
18. Basement -Water Piping -(SPRWS 93.07) Provide a one (1) inch water line to the first major take off.
19. Basement -Water Piping -(MPC .0100 P & Q) Provide water piping to all fixtures and appliances.
20. Basement -Water Piping -(MPC 610) Replace all the improperly sized water piping.
21. Basement -Water Piping -(MPC 301.1 (3))Repair or replace all the corroded, broken, or leaking water piping.
22. Bathroom -Plumbing - General -(MPC 402.2) Provide a water tight joint between the fixture and the wall or floor.
23. Exterior -Rain Leader -(MPC .0100 L & M & 708.1) The rain leaders must be properly plugged or capped to code.
24. First Floor -Gas Piping -(MFGC 411) Install an approved shut off; connector and gas piping for the range.
25. First Floor -Lavatory -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
26. First Floor -Lavatory -(MPC 701) Install the waste piping to code.
27. First Floor -Lavatory -(MPC .0100 E & 901) Install a proper fixture vent to code.
28. First Floor -Sink -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
29. First Floor -Sink -(MPC .0100 P & Q & 419.2) Install the water piping to code.
30. First Floor -Sink -(MPC 701) Install the waste piping to code.
31. First Floor -Sink -(MPC .0100 E & 901) Install a proper fixture vent to code.
32. First Floor -Toilet Facilities -(MPC 402.6) Install a proper flanged fixture connection on a firm base.
33. First Floor -Toilet Facilities -(MPC 301.1) Repair/replace the fixture that is missing, broken or has parts missing.
34. First Floor -Tub and Shower -(MPC 408.3) Install scald and thermal shock protection, ASSE Standard 1016.
35. First Floor -Tub and Shower -(MPC 701) Install the waste piping to code.
36. First Floor -Tub and Shower -(MPC .0100 E & 901)Install a proper fixture vent to code.

37. All the above corrections to waste, vent, water, and gas piping shall be per the Minnesota Plumbing Code Chapter 4714, Minnesota Rules Chapter 326, 4716, 1300, the Minnesota Mechanical Code, the Minnesota Fuel Gas Code, and Saint Paul Regional Water Services Water Code. All plumbing must be done by a plumbing contractor licensed in the State of Minnesota and the City of St. Paul by a plumber licensed in the State of Minnesota who also possess a City of Saint Paul Competency Card and after obtaining an approved City of Saint Paul Plumbing Permit.

Heating Inspector: Aaron Havlicek

Phone: 651-266-9043

1. Install approved level handle manual gas shutoff valve on furnace/boiler and remove unapproved valve.
2. Install approved lever handle manual building shutoff gas valve in an accessible location ahead of the first branch tee.
3. Clean and Orsat test furnace/boiler burner. Check all controls for proper operation. Check furnace heat exchanger for leak; provide documentation from a licensed contractor that the heating unit is safe.
4. Install approved metal chimney liner.
5. Replace furnace/boiler flue venting to code.
6. Connect furnace/boiler and water heater venting into chimney liner.
7. Vent clothes dryer to code and provide approved gas piping and valve (plumbing or mechanical gas permit is required).
8. Provide adequate combustion air and support duct to code.
9. Provide support for gas lines to code.
10. Plug, cap and/or remove all disconnected gas lines, non-conforming gas lines and unapproved valves.
11. Bathrooms require a means to ventilate the space. Provide a window with an aggregate glazing area of not less than 3 square feet, one half of which must be operable. Alternative is a bath fan properly vented to the outside. All kitchen exhaust must be venting to exterior. A mechanical ventilation permit will be required for the bath fan and/or kitchen exhaust.
12. Provide heat in every habitable room and bathrooms.
13. Attach metal tag to expansion tank valve stating that this valve must be open at all times except when draining the expansion tank.
14. Support supply and return piping from heating system according to code.
15. Conduct witnessed pressure test on hot water heating system and check for leaks.
16. Install boiler pressure relief valve and pipe discharge to within 18 inches of the floor.
17. Install back flow preventer on city water fill line to hot water heating system and pipe vent as required.
18. Repair or replace radiator valves as needed.
19. Mechanical permits are required for the above work.

20. Conduct witnessed pressure test on gas piping system and check for leaks.

Notes:

1. See attachment for permit requirements and appeals procedure.

This is a registered vacant building. In order to sell or reoccupy this building, all deficiencies listed on this code compliance report must be corrected in accordance with the Minimum Housing Standards of the St. Paul Legislative Code (Chapter 34) and all required permits must receive final approval within six (6) months of the date of this report. One (1) six-month time extension may be requested by the owner and will be considered if it can be shown that the code compliance work is proceeding and is more than fifty (50) percent complete in accordance with Legislative Code Section 33.03(f).

You may file an appeal to this notice by contacting the City Clerk's Office at 651-266-8688. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this notice when you appeal, and pay a filing fee.)

If you have any questions regarding this inspection report, please contact Nathan Bruhn between 7:30 - 9:00 AM at 651-266-9033 or leave a voice mail message.

Sincerely,

Nathan Bruhn
Code Compliance Officer
Department of Safety and Inspections
City of Saint Paul
375 Jackson Street, Suite 220
Saint Paul MN 55101
Phone: 651-266-9033
Email: nathan.bruhn@ci.stpaul.mn.us

Attachments