

375 Jackson Street, Suite 220 Saint Paul, MN 55101-1806 Tel: 651-266-8989 | Fax: 651-266-9124

February 8, 2024

Community Stabilization Project 501 DALE ST N ST PAUL MN 55103

## NOTICE OF CONDEMNATION UNFIT FOR HUMAN HABITATION ORDER TO VACATE

RE: 1056 HATCH AVE Ref. # 124152

Dear Property Representative:

Your building was inspected on February 8, 2024.

The building was found to be unsafe, unfit for human habitation, a public nuisance, a hazard to the public welfare or otherwise dangerous to human life. A Condemnation Placard has been posted on the building.

The following deficiency list must be completed or the building vacated by the re-inspection date.

## CONDEMNATION OF THE BUILDING REVOKES THE CERTIFICATE OF OCCUPANCY.

Failure to complete the corrections may result in a criminal citation. The Saint Paul Legislative Code requires that no building be occupied without a Fire Certificate of Occupancy.

## DEFICIENCY LIST

1. SPLC 34.23, MSFC 111.1 - This occupancy is condemned as unsafe or dangerous. This occupancy must not be used until re-inspected and approved by this office. - This building is condemned due to gas service being locked off by Xcel Energy and due to lack of approved heating system. Furnace has been red-tagged due to unsafe venting.

- 2. Basement Stairway SPLC 34.10 (3), 34.34(2) Repair or replace the damaged handrail in an approved manner.
- 3. Basement MFGC 503 Provide, repair or replace the fuel equipment vent or vent liner to develop a positive flow adequate to convey all products of combustion to the outside. This work will require a permit(s). Call DSI at (651) 266-8989. Furnace exhaust duct rusted through and vented through the wall and under the deck. Furnace has been red-tagged by Xcel Energy and gas service to building was locked due to unsafe venting.
- 4. Bathroom NEC 406.4(D)(3) GFCI outlets shall be provided where replacements are made at outlets that are required to be so protected elsewhere in this Code. GFCI not functioning correctly. Did not trip when tested.
- 5. Front of house SPLC 34.08 (5), 34.32 (3) All accessory structures including, but not limited to, detached garages, sheds and fences shall be maintained structurally sound and in good repair. Provide and maintain exterior unprotected surfaces painted or protected from the elements. Fence is leaning into sidewalk
- 6. Kitchen Stove MSFC 604.1 Repair or replace damaged electrical appliance wiring. This work may require a permit(s). Call DSI at (651) 266-8989.-Correctly wire electric stove which has been hard-wired directly to panel with flexible cord.
- 7. Rear door Deck SPLC 34.09 (3), 34.33(2) Repair or replace the unsafe stairways, porch, decks or railings in an approved manner. Every outside stair, porch and deck shall be constructed safely and shall be capable of supporting imposed loads as determined in the building code and shall be kept in a professional state of maintenance and repair with proper anchorage. This work may require a permit(s). Call DSI at (651) 266-8989.-Railing is not installed and middle area is sagging.
- 8. Rear of the house SPLC 34.08 (1), 34.32 (1) Sanitation. All exterior property areas shall be maintained in a clean, safe and sanitary condition, free from any accumulation of garbage, mixed municipal solid waste, animal feces or refuse. Piled up trash by the front of the garage.
- 9. Side of house SPLC 34.12 (2), SPLC 34.36 (1) Repair and maintain all required and supplied equipment in an operative and safe condition to properly and safely perform their intended function in accordance with the provisions of the applicable code.-Repair communication cable that was pulled out of house
- 10. SPLC 39.02(c) Complete and sign the smoke alarm affidavit and return it to this office.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse,

15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of the original orders.

If you have any questions, email me at: Michael.P.Tschida@ci.stpaul.mn.us or call me at 651-266-1917 between 7:30 - 9:00 a.m. Please help make Saint Paul a safer place in which to live and work.

Sincerely,

Michael P Tschida

Ref. # 124152

cc: Housing Resource Center Force Unit