

375 Jackson Street, Suite 220 Saint Paul, MN 55101-1806 Tel: 651-266-8989 | Fax: 651-266-9124

February 14, 2023

James Richter 146 KIVELA ROAD NEGAUNEE MI 49866USA

Revocation of Fire Certificate of Occupancy and Order to Vacate

RE: 1222 7TH ST W

Ref. # 108046

Dear Property Representative:

Your building was determined to be a registered vacant building on February 10, 2023. Since certificates are for the occupancy of buildings, it has become necessary to revoke the Certificate of Occupancy.

Saint Paul Legislative Code provides that no building shall be occupied without a Certificate of Occupancy. In order to re-occupy the building, the following deficiencies (if applicable) must be corrected and a complete Certificate of Occupancy inspection will be required.

DEFICIENCY LIST

- 1. Unit 1222 Basement SPLC 34.11 (6), 34.35 (3) Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Existing Fuel Burning Equipment Safety Test Report to this office.-
 - Clean out door and chimney needs to shut.
- 2. Unit 1222 & 24 Basement MMC 504.1 Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-8989.
- 3. Unit 1224 2nd floor Bathroom NEC 406.4(D)(3) GFCI outlets shall be provided where replacements are made at outlets that are required to be so protected elsewhere in this Code.-GFI not working properly, shows open ground and will not trip when tested.

- 4. Unit 1224 2nd floor Bathroom SPLC 34.10 (4), 34.34 (3) Provide a bathroom floor impervious to water to permit such floor to be easily kept in a clean and sanitary condition-Tile missing around heat vent.
- 5. Unit 1224 Bedroom MN Stat. 299F.362, MSFC 1103.8 Immediately provide and maintain a smoke alarm located outside each sleeping area.-Missing smoke alarm , 2nd floor bedroom.

Saint Paul Legislative Code authorizes this inspection and collection of inspection fees. For forms, fee schedule, inspection handouts, or information on some of the violations contained in this report, please visit our web page at: http://www.stpaul.gov/cofo

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8585) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: Frank.Thurner@ci.stpaul.mn.us or call me at 651-266-8984 between 7:30 - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Frank Thurner Fire Safety Inspector

Ref. # 108046