



- Yog hais tias koj tsis to taub tsab ntawv no, hu rau tus txhais lus ntawm (651) 266-8989. Nws yuav pab dawb xwb.
- Si necessita un traductor, por favor llamanos al (651)266-8989. No costo.

April 19, 2024

Colleen Mulcahy/Paul Mulcahy  
272 Richmond St  
St Paul MN 55102-3144

## CORRECTION NOTICE

Date: **April 19, 2024**  
RE: **272 RICHMOND ST**  
File #: **24-021221**

Dear Sir/Madam:

The City of Saint Paul, Department of Safety and Inspections has inspected the above referenced property on **April 19, 2024** and has determined that the following deficiencies exist in violation of the Saint Paul Legislative Code<sup>1</sup> (see footnote 1, below).

1. SPLC 34.19. – **ACCESS:** Provide access to the inspector to all areas of the building and garage.
2. SPLC 34.08. - **ACCESSORY STRUCTURES/FENCES:** All accessory structures including, but not limited to, detached garages, sheds, retaining walls and fences shall be kept in a professional state of maintenance and repair and maintained structurally sound. All exterior wood surfaces, other than decay-resistant woods, shall be protected from the elements and decay by paint which is not lead-based paint or by other protective covering or treatment. Service doors to accessory structures shall be provided with securing locks.
3. SPLC 34.09. - **DECK/STAIRWAY:** Repair or replace the unsafe stairways, porch, decks, guardrails, and handrail in a professional state of maintenance and repair. This work requires a permit(s). Call DSI at (651) 266-9090.
4. SPLC 34.09. - **DOOR(S):** All doors interior and exterior and its hardware shall be in sound condition and fit within its frame. Doors shall be maintained in a professional state of maintenance and repair. Repair or replace the damaged door, hardware, or frame.
5. SPLC 34.08. - **EXTERIOR SANITATION:** All exterior property areas shall be maintained free from any accumulation of refuse, garbage, or feces. Remove the accumulation of exterior storage that creates a nuisance or harbors rodents.

6. SPLC 34.09. - **LOCKS/DEADBOLT:** Lacking deadbolt door locks. Provide one-inch throw deadbolt locks for all entry doors to dwelling unit(s).
7. SPLC 34.08. - **PARKING:** Parked or stored vehicles. All existing parking spaces shall consist of asphalt, concrete, gravel rock, or other durable and dustless surfaces. Existing parking surfaces must be maintained in a professional state of repair and may be maintained with like materials without additional approval from the city. Existing parking surfaces must be contained to eliminate migration onto other adjacent surfaces and must be clearly delineated. In all residential districts, off street parking shall not be located within any front yard or non-interior side yard. Before any existing parking spaces or driveways may be expanded upon, site plan approval must be obtained as specified in the Saint Paul Zoning Code and the lot must be developed in conformance with such approval. DISCONTINUE PARKING IN THE YARD.
8. SPLC 34.09. - **ROOF:** Provide and maintained the roof weather tight and kept in a professional state of maintenance and repair, impervious to water and have no defects which admit water or dampness to the interior of the building. This requires a permit (s). Call DSI at (651) 266-9090.
9. SPLC 34.08. - **EXTERIOR SANITATION:** All exterior property areas to be maintained in a clean, safe, and sanitary condition, free from accumulation of garbage, mixed municipal solid waste, animal feces or refuse. Immediately remove improperly stored or accumulated refuse including garbage, rubbish, junk, vehicle parts, wood, metal, recycling materials, household items, building materials, rubble, and/or tires from the property, boulevard, driveway, alley, and yard.
10. SPLC 34.08. - **VEHICLES:** All vehicles must be correctly licensed, operable, secure from unauthorized entry, and parked on an improved surface. Correct violations, store in a garage or remove.
11. SPLC 34.09. - **WINDOWS:** Repair and maintain the window in good condition including the glass, sash, frame, and screens. Windows shall be without cracks or holes, sashes shall be in sound conditions, the window shall be easily opened and maintain the open position. All screens shall be maintained in a professional state of maintenance and repair.
12. SPLC 34.15. - **CARBON MONOXIDE ALARM:** Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturer's instructions.
13. SPLC 34.10. - **CEILINGS:** All ceilings must be maintained in a sound condition and in a professional state of maintenance and repair.

14. SPLC 33.03 (c). - **DRYER VENTING:** Provide, repair, or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter and installed in accordance with the mechanical code. This work may require a permit(s). Call DSI at (651) 266-8989. RECONNECT THE DRYER VENT TO MEET CODE.
15. SPLC 34.14 (2). - **ELECTRICAL PANEL CLEARANCE:** Provide and maintain a minimum of 36 inches clearance in front of all electrical panels.
16. SPLC 34.11. - **ELECTRICITY:** Have the hard-wired smoke detector repaired or replaced by a licensed electrician under permit. Remove all extension cords from the interior and exterior of home.
17. SPLC 34.10. - **FLOORS:** All floors must be maintained in a sound condition and in a professional state of maintenance and repair.
18. SPLC 45.03. - **INTERIOR SANITATION:** The interior shall be maintained in a clean and sanitary condition, free from any accumulation of refuse or garbage.
19. SPLC 34.09. - **LOCKS/DEADBOLT:** Lacking deadbolt door locks. Provide one-inch throw deadbolt locks for all entry doors to dwelling unit(s).
20. SPLC 45.03. - **MECHANICAL CLEARANCE:** Provide 30 inches clearance around all mechanical equipment including the furnace and water heater.
21. SPLC 34.15. - **SMOKE DETECTOR:** The occupant of a dwelling unit must inform the owner of the dwelling unit of a nonfunctioning smoke detector within 24 hours of discovering that the smoke detector in the dwelling unit is not functioning. Smoke detector may not be tampered with or disabled at any time. Immediately provide and maintain a smoke detector located outside each sleeping area.
22. SPLC 34.10. - **INTERIOR STAIRS:** Every flight of stairs shall be maintained in a professional state of maintenance and repair. Every required handrail and guard shall be firmly fastened and capable of supporting imposed loads and shall be maintained in a professional state of maintenance and repair.
23. SPLC 34.12. - **SUPPLIED EQUIPMENT:** Repair and maintain all required and supplied equipment in an operative and safe condition to perform their intended function properly and safely in accordance with the provisions of the applicable code. HAVE ALL PERMITS INSPECTED AND APPROVED FOR THE BOILER AND WATER HEATER.
24. SPLC 34.10. - **WALLS:** All walls must be maintained in a sound condition and in a professional state of maintenance and repair.

You are hereby notified to correct these deficiencies in accordance with the appropriate codes. The Enforcement Officer will re-inspect these premises on or after **Items number 1,4,6,12,14,15,16,19,20,21,and 23 must be completed by May 06, 2024 all other items by June 6, 2024**, by which date the violations noted must be corrected. Failure to correct these deficiencies may result in an abatement and/or additional fees for re-inspection.

You may file an appeal to this notice by contacting the City Clerk at 651-266-8585. Any appeal must be made in writing within 10 days of this notice. (You must submit a copy of this Notice when you appeal and pay a filing fee.)

**If you have any questions or request additional information, please contact me. To arrange an appointment or request an extension of time to complete repairs, you will need to speak directly to me at 651-266-1940.**

Sincerely,

**Lisa Martin**  
**Badge # 335**  
**CODE ENFORCEMENT OFFICER**

Footnote:

- <sup>1</sup> To see the Legislative Code go to [www.stpaul.gov](http://www.stpaul.gov) on the internet, click on "Departments", then click on "Department of Safety and Inspections", scroll down the page for the "Codes". Most Correction Notices derive from Chapter 34.

**WARNING:** Code inspection and enforcement trips cost the taxpayers money. If the violations are not corrected within the time period required in this notice, the city's costs in conducting a reinspection for compliance after the due date will be collected from the owner rather than being paid for by the taxpayers of the City. If additional new violations are discovered within the next following 12 months, the city's costs in conducting additional inspections at this same location within said 12 months will be collected from the owner rather than being paid for by the taxpayers of the City. Any such future costs will be collected via assessment against the real property and are in addition to any other fines or assessments which may be levied against you and your property.