



APPLICATION FOR APPEAL

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

RECEIVED

NOV 22 2010

CITY CLERK

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed

YOUR HEARING Date and Time:

Tuesday, 12/7/10

Time 1:30

Location of Hearing:

Room 330 City Hall/Courthouse

Address Being Appealed:

Number & Street: 440 Cherokee Avenue City: St. Paul State: MN Zip: 55107

Appellant/Applicant: Beissel Window and Siding Email jeff@beisselwindows.com

Phone Numbers: Business 651-451-6835 Residence _____ Cell _____

Signature: *Jeff W Beissel* Date: _____

Name of Owner (if other than Appellant): Daniel Vickery

Address (if not Appellant's): 440 Cherokee Avenue, St. Paul, MN 55107

Phone Numbers: Business 492-5109 Residence _____ Cell _____

What Is Being appealed and why?

Attachments Are Acceptable

- Vacate Order/Condemnation/
- Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other Egress Variance see attached
- Other
- Other



CITY OF SAINT PAUL
INTERDEPARTMENTAL MEMORANDUM

EGRESS WINDOW NON-COMPLIANCE DETERMINATION

TO: CITY CLERK
15 KELLOGG BLVD. WEST
310 CITY HALL
SAINT PAUL, MN 55102

PHONE: 651-266-8688
FAX: 651-266-8574

DATE: November 16, 2010

APPEAL PROPERTY ADDRESS: 440 CHEROKEE AVE
APPLICANT NAME: BEISSEL WINDOW & SIDING CO
PHONE NUMBER: 651-266-9074
PERMIT NUMBER: 10 920400
TYPE OF WINDOW Double Hung
NUMBER OF WINDOWS 5

Total Glazed Area	7.42	Difference from Required Area	+2.42
Width of Opening	26 ¼	Difference from Required Opening	+6 ¼
Height of Opening	21 ¾	Difference from Required Opening	-2 ¼
Height of Opening to Finished Floor	27	Difference from Maximum Height	ok

COMMENTS: With the information provided above approval is recommended. 11-16-10 rr

Reviewed by: Rehn