

Gaviota Construction. Inc

Siding, Roofing, Gutters, Painting, Flooring, Dry wall & more.

1062 Arcade Street, Saint Paul, MN 55106

651-340-4682 Office * 651-787-3482 Fax 651 797 3482

To:	Gas Station / Khadra	<u>Estimate</u>		
Expect date	Open	Date: Project # License#		10/08/15 172015 BC635994
Address:	719 Payne Ave, St Paul. MN			
Telephone:	6517933568			
Email:				
Type of Job:	Plumbing			
Item	Description	Sqs/ EA	Cost Unit	Subtotal
<u>The following bid included, materials & labor hands</u>				
1	The gas meter is at the rear of the building and is locked. Plumbing Trade.- Provide an approved number and type of plumbing fixtures. Plumbing Trade.- Repair or Replace and maintain the plumbing fixture to an operational condition.			
2	Water heater: corrections required. (MPC 2210 Subp. 4) -t & p relief discharge piping incorrect. (MPC 1730 Subp. 1) - water piping incorrect. (MPC 2180)- NOT FIRED OR IN SERVICE. Water piping: corrections required (MPC 1720)- Repair or replace all corroded, broken or leaking piping. (MPC 1730) - pipe sizing incorrect. (MPC 0420) - Improper fittings or usage. (MPC 0520)- Improper piping or usage. (MPC 1700)- Provide water piping to all fixture & appliances. Gas piping: corrections required: (MFGC 402) - Pipe sizing incorrect. (MEGC 406 1)-Retest all gas for excel meter unlock			
3	Set and Install according MN codes all piping and plumbing as need for new kitchen, (fixtures not included) and 1 bathroom, inside or building.			

Thanks For The Work Opportunity
License, Bonded, Insurance & BBB.
We will charge all additional job don't included in this bid.
We are dedicate to make only to quality job

Contact Us	Harold Fajardo (651) 3876951 Office: (651) 447-2082 Fax: (651) 797-3482 harold@gaviotaconstruction.com www.gaviotaconstruction.com	Gross	\$12,633.00
		Total Bid	\$12,633.00