



APPLICATION FOR APPEAL

RECEIVED

SEP 15 2011

CITY CLERK

Saint Paul City Clerk

310 City Hall, 15 W. Kellogg Blvd.

Saint Paul, Minnesota 55102

Telephone: (651) 266-8560

The City Clerk needs the following to process your appeal:

- \$25 filing fee payable to the City of Saint Paul (if cash: receipt number _____)
- Copy of the City-issued orders or letter which are being appealed
- Attachments you may wish to include
- This appeal form completed
- Walk-In OR Mail-In

YOUR HEARING Date and Time:

Tuesday, 10-4-11

Time 1:30

Location of Hearing:
Room 330 City Hall/Courthouse

mailed 9-15-11

Address Being Appealed:

Number & Street: 3227 Scheffer Ave City: St. Paul State: MN Zip: 55116

Appellant/Applicant: Bob Fenlon Email _____

Phone Numbers: Business 612-335-1437 Residence St Paul 651-414-0548 Cell 612-600-8372

Signature: *Robert Fenlon* Date: _____

Name of Owner (if other than Appellant): _____

Address (if not Appellant's): _____

Phone Numbers: Business _____ Residence _____ Cell _____

What Is Being Appealed and Why? *Attachments Are Acceptable*

- Vacate Order/Condemnation/Revocation of Fire C of O
- Summary/Vehicle Abatement
- Fire C of O Deficiency List
- Fire C of O: Only Egress Windows
- Code Enforcement Correction Notice
- Vacant Building Registration
- Other

Requirement to provide & maintain approved egress windows. Our windows are plenty large enough to escape through, but are slightly smaller than code requirements. Our inspector said he thought the City will award this requirement.



CITY OF SAINT PAUL
Christopher B. Coleman, Mayor

375 Jackson Street, Suite 220
Saint Paul, Minnesota 55101-1806

Telephone: 651-266-8989
Facsimile: 651-266-8951
Web: www.stpaul.gov/dsi

July 7, 2011

ROBERT FENLON
MARY FENLON
1984 STANFORD AVE
ST PAUL MN 55105-1654

FIRE INSPECTION CORRECTION NOTICE

RE: 2222 SCHEFFER AVE
Residential Class: C

Dear Property Representative:

Your building was inspected on July 7, 2011 for the renewal of your Fire Certificate of Occupancy. Approval for occupancy will be granted upon compliance with the following deficiency list. The items on the list must be corrected prior to the re-inspection date.

A re-inspection will be made on August 10, 2011 at 11:15AM.

Failure to comply may result in a criminal citation or the revocation of the Fire Certificate of Occupancy. The Saint Paul Legislative Code requires that no building shall be occupied without a Fire Certificate of Occupancy. The code also provides for the assessment of additional re-inspection fees.

YOU WILL BE RESPONSIBLE FOR NOTIFYING TENANTS IF ANY OF THE FOLLOWING LIST OF DEFICIENCIES ARE THEIR RESPONSIBILITY.

DEFICIENCY LIST

1. Basement - SPLC 34.10 (5), 34.33 (4), 34.16 - Provide and maintain interior in a clean and sanitary condition.-Maintain area free of dog feces.
2. Basement - UMC 1346.703 - Provide 30 inches clearance around all mechanical equipment.
3. Garage - SPLC 71.01 - The address posted is not visible from street. (HN-1)

4. Throughout - MSFC 605.6 - Provide electrical cover plates to all outlets, switches and junction boxes where missing.
5. SPLC 34.11 (6), 34.34 (3) - Provide service of heating facility by a licensed contractor which must include a carbon monoxide test. Submit a completed copy of the Saint Paul Fire Marshal's Existing Fuel Burning Equipment Safety Test Report to this office.
6. SPLC 39.02(c) - Complete and sign the provided smoke detector affidavit and return it to this office.
7. UMC 504.6 - Provide, repair or replace the dryer exhaust duct. Exhaust ducts for domestic clothes dryers shall be constructed of metal and shall have a smooth interior finish. The exhaust duct shall be a minimum nominal size of four inches (102 mm) in diameter. This work requires a permit(s). Call DSI at (651) 266-8989.
8. MSFC 901.6 - Provide required annual maintenance of the fire extinguishers by a qualified person and tag the fire extinguishers with the date of service.
9. MN State Statute 299F.50 Immediately provide and maintain an approved Carbon Monoxide Alarm in a location within ten (10) feet of each sleeping area. Installation shall be in accordance with manufacturers instructions.
10. SPLC 200.02 (a) No person shall own, harbor, keep or maintain in the City and dog over three months of age without a license. Provide written documentation of current license to the Fire Inspector. To obtain a dog license, contact DSI at 651-266-8989
11. MSFC1026.1 - Provide and maintain an approved escape window from each sleeping room. The minimum size must be 5 square feet of glazed area with a minimum of 24 inches of openable height and 20 inches of openable width. With a finished sill height not more than 48 inches. This work may require permit(s). Call DSI at (651)- 266-9090. Refer to the Escape Windows for Residential Occupancies handout for more information.-
First floor north
20.5 h x 24 w Glazed 6.7 sq ft
First floor south
20.5 h x 24 w Glazed 6.7 sq ft

For an explanation or information on some of the violations contained in this report, please visit our web page at: <http://www.ci.stpaul.mn.us/index.aspx?NID=211>

You have the right to appeal these orders to the Legislative Hearing Officer. Applications for appeals may be obtained at the Office of the City Clerk, 310 City Hall, City/County Courthouse, 15 W Kellogg Blvd, Saint Paul MN 55102 Phone: (651-266-8688) and must be filed within 10 days of the date of this order.

If you have any questions, email me at: rick.gavin@ci.stpaul.mn.us or call me at 651-266-8994 between 7:30 a.m. - 9:00 a.m. Please help to make Saint Paul a safer place in which to live and work.

Sincerely,

Rick Gavin
Fire Inspector